



United States Environmental Protection Agency (EPA)

Region 2

290 Broadway

New York, NY 10007-1866

Underground Storage Tank (UST) Inspection Form

INSPECTOR NAME(S):

JEFF BLAIR

DATE:

03/18/13

SIC CODE:

ICIS #:

3400023736

I. Location of Tank(s)

☐ Tribal

Facility Name

GETTY # 377

Street Address

40 NORTH MAIN STREET

City

State

Zip Code

NEW CITY, NY

10956

County

ROCKLAND

Phone Number

Fax Number

N/A

Contact Person(s)

CHRIS MARKOU, TERRITORY
MANAGER

II. Ownership of Tank(s)

☐ same as location (I.)

Owner Name

AOC TRANSPORT/GETTY REALTY

Street Address

125 JERICHO TURNPIKE

City

State

Zip Code

JERICHO, NY

11753

County

Phone Number

Fax Number

(516) 478-5468 (516) 478-5476

Contact Person(s)

JOHN DEMONTE, MANAGER -
FACILITIES

IIA. Ownership of Other Facilities

☐ Do you own other UST Facilities Yes/No

If Yes, How many Facilities 210 (NYS)

How many USTs 652 (NYS)

III. Notification

☐ Notification to implementing agency; name
State Facility ID # 3-990136

ROCKLAND
CO DOH (EFFECTIVE THROUGH 10/01/15)

IV. Financial Responsibility

☐ State Fund

☐ Guarantee

☐ Local Government

☐ Surety Bond

☒ Self Insured

☐ Private Insurance: Insurer/Policy #

☐ Letter of Credit

☐ Not Required (Federal & State government, hazardous substance USTs)

V. Release History

N/A ☒

☐ To your knowledge, are there any public or private Drinking Water Wells in the vicinity? Yes No

☐ Evidence of release or spills at facility

☐ Greater than 25 gallons (estimate)

☐ Releases reported to implementing agency; if so, date(s) [280.53]

☐ Release confirmed; when and how

☐ Initial abatement measures and site characterization

☐ Soil or ground water contamination

☐ Remediation ongoing

☐ Free product removal

☐ Corrective action plan submitted

☐ Remediation completed, no further action; date(s)

Notes:

VI. Tank Information		Tank No.	1	2	3			
Tank presently in use			NO					
If not, date last used (see Section XII)			NOV 2011					
If empty, verify 1" or less left (see Section XII)			NO					
Capacity of Tank (gal)			6000G	8000G	10000G			
Substance Stored			GASOLINE					
M/Y Tank <u>installed</u> / Upgraded			02/9					
<u>Tank Construction:</u> Bare steel, Sti-P3, Retrofitted sacrificial anode, Impressed Current, Composite, FRP, Interior lining, Vaulted, Double-walled (DW)			FRP					
Spill Prevention			SPILL BUCKETS					
Overfill Prevention (specify type)			N/A					
<u>Special Configuration:</u> Compartmentalized, Manifolded			NO					

VII. Piping Information

<u>Piping Type:</u>	Pressure, Suction	PRESSURE				
<u>Piping Construction:</u>	Bare steel, Sacrificial Anode, Impressed Current, Flex, FRP, Double-walled (DW)	FRP				

Tank and Piping Notes:

DROP TUBES WITH 1000 SHUTOFFS REMOVED, BUT REMAIN ON-SITE
~~ALSO WAS HLA FOR OVERFILL TESTED (OK) JKB~~

VIII. Cathodic Protection

N/A ☒

Integrity Assessment conducted prior to upgrade						
<u>Interior Lining:</u>	Interior lining inspected					
<u>Impressed Current</u>	CP Test records					
	Rectifier inspection records					
<u>Sacrificial Anode:</u>	CP test records					

CP Notes:

Tank No.	1	2	3			
IX. UST system used solely by Emergency Power Generator	NO					

X. Release Detection

N/A ☐Tank RD Methods

ATG						
Interstitial Monitoring						
Groundwater Monitoring						
Vapor Monitoring						
Inventory Control w/ TTT						
Manual Tank Gauging						
Manual Tank Gauging w/ TTT						
SIR	YES					

12 Months Monitoring Records (Must Make Available Last 12 Months For Compliance)

YES

Tank RD Notes: (State What Months Records Were Available, Describe Any Failures and Describe What Investigation Occurred Due to Failure)

I REVIEWED TWELVE PREVIOUS MONTHS OF PASSING SIR RESULTS
TANK MONITOR → OMNITEC GEL 8000 II

Pressurized Piping RD MethodsN/A ☐

Interstitial Monitoring						
Groundwater Monitoring						
Vapor Monitoring						
SIR						

12 Months Monitoring Records

ALLD

Annual Line Tightness Test	YES					
Present	YES					
Annual Test	YES					

Piping RD Notes: (State What Months Records Were Available, Describe Any Failures and Describe What Investigation Occurred Due to Failure)

I REVIEWED PASSING LEAK DETECTOR AND PRESSURIZED WIRE TEST RESULTS (TEST DATE 03/10/11, TANKS UNUSED) SINCE NOV 2011

XI. RepairsN/A ☒

Repaired tanks and piping are tightness tested within 30 days of repair completion

Y ☐ N ☐ Unknown ☐

CP systems are tested/inspected within 6 months of repair of any cathodically protected UST system

Y ☐ N ☐ Unknown ☐

Records of repairs are maintained

Y ☐ N ☐ Unknown ☐**XII. Temporary Closure**N/A ☒

CP continues to be maintained

Y ☐ N ☐ Unknown ☐

UST system contains product and release detection is performed

Y ☐ N ☐ Unknown ☐

Cap and secure all lines, pumps, manways

Y ☐ N ☐ Unknown ☐**Notes:** ☒

GASSED ALL THREE TANKS DURING INSPECTION:

MID GRADE → 2 1/2", NO WATER

PREMIUM → 1 1/2", NO WATER

REGULAT → 1 1/4", NO WATER

3-990136



THE UNITED STATES ENVIRONMENTAL PROTECTION AGENCY (EPA) REGION 2 UST
PROGRAM
Ground Water Compliance Section
New York, NY 10007-1866

Inspector Observation Report
Inspection of Underground Storage Tanks (USTs)

☒ No violations observed at the conclusion of this inspection.

☐ The above named facility was inspected by a duly authorized representative of EPA Region 2, and the following are the inspector's observations and/or recommended corrective action(s):

Violations Observed:

Regulatory Citation	Violation Description
\$	
\$	
\$	
\$	
\$	
\$	
\$	
\$	

Actions Taken:

☐ Field Citation; # _____ ☐ Additional information required ☐ On-site request/Due date _____

Comments/Recommendations:

Name of Owner/Operator Representative:

Chris M. [Signature]
(Please print)
(Signature)




Other Participants: _____

Name of EPA Inspector/representative

JEFFREY K BLAIR
(Please print)
Jeffrey K Blair
(Signature)

(Credential Number)

Date of Inspection 03/18/13 Time 4:15 AM/PM PM

SITE DRAWINGDATE: 03/13/13 TIME ON SITE: 3:25 PM TIME OFF SITE: 4:15 PMWEATHER: 45° + OVERCASTENVIRONMENTALLY SENSITIVE AREA: Y ☐ N ☒
If "Yes", please describe:PHOTOS

- 381 FP MID
382 STP MID
383 FP PRE
384 STP PRE
385 FP REG
R 386 STP REG
P 387 FUEL PAD
M 388 DROP TUBES
389 TANK MONITOR
390 GAUGE STICK MID
391 GAUGE STICK PRE
392 GAUGE STICK REG
393 SITE

Pictures

Required Fields to be used for ICIS OnlyCompliance Monitoring

Activity: UST Inspection

Inspection Conclusion Data Sheet1) Did you observe deficiencies (preferred violations) during the on-site inspection? **NS**

Deficiencies observed: (Put an X for each observed deficiency)

☐ Potential failure to complete or submit a notification, report, certification, or manifest☐ Potential failure to follow or develop a required management practice or procedure☐ Potential failure to maintain a record or failure to disclose a document☐ Potential failure to maintain/inspect/repair meters, sensors, and recording equipment☐ Potential failure to report regulated events, such as spills, accidents, etc.2) If you observed deficiencies, did you communicate the deficiencies to the Facility during the inspection? **Yes / No**3) Did you observe the Facility take any actions during the inspection to address the deficiencies noted? **Yes / No**

If yes, what actions were taken?

4) Did you provide general Compliance Assistance in accordance with the policy on the role of the EPA Inspector in providing Compliance Assistance during Inspections? **Yes / No**5) Did you provide site-specific Compliance Assistance in accordance with the policy on the role of the EPA Inspector in providing Compliance Assistance during the inspection? **Yes / No**

3-280136

Release Prevention Compliance Measures Matrix

Regulatory Subject Area	Measure #	SOC Measure / Federal Citation	In Compliance?		
			N/A	Y	N
I. Spill Prevention	1	Spill prevention device is present and functional. [280.20(c)(1)(i), 280.21(d)]	<input checked="" type="checkbox"/>		
II. Overfill Prevention	2	<p>Overfill prevention device is present and operational. [280.20(c)(1)(ii), 280.21(d)]</p> <p><input type="checkbox"/> Automatic shutoff is operational (ie., device not tampered with or inoperable) [280.20(c)(1)(ii)(A), 280.21(d)]</p> <p><input type="checkbox"/> Alarm is operational. [280.20(c)(1) (ii)(B), 280.21(d)]</p> <p><input type="checkbox"/> Alarm is audible or visible to delivery driver. [280.20(c)(1) (iii)(B), 280.21(d)]</p> <p><input type="checkbox"/> Ball float is operational. [280.20(c)(1)(iii)(B), 280.21(d)]</p>	<input checked="" type="checkbox"/>		
III a. Operation and Maintenance	3	Repaired tanks and piping were tightness tested within 30 days of repair completion (not required w/internal inspections or if monthly monitoring is in use). [280.33(d)]	<input checked="" type="checkbox"/>		
III b. Operation and Maintenance of Corrosion Protection	4	CP systems were tested/inspected within 6 months of repair of any cathodically protected UST system. [280.33(e)]	<input checked="" type="checkbox"/>		
	5	<p>Corrosion protection system is properly operated and maintained to provide continuous protection. [280.31(a)(b), 280.70(a)]</p> <p><input type="checkbox"/> UST system (Choose one)</p> <p><input type="checkbox"/> UST in operation</p> <p><input type="checkbox"/> UST in temporary closure</p> <p><input type="checkbox"/> CP System is properly operated and maintained</p> <p><input type="checkbox"/> CP system is performing adequately based on results of testing. [280.31(b)]; - or -</p> <p><input type="checkbox"/> CP system tested within required period and operator is conducting CP system not providing adequate protection.</p>	<input checked="" type="checkbox"/>		

Release Prevention Compliance Measures Matrix

Regulatory Subject Area	Measure #	SOC Measure / Federal Citation	In Compliance?		
			N/A	Y	N
III b. Operation and Maintenance of Corrosion Protection (Continued)	6	UST systems with impressed current cathodic protection are inspected every 60 days. [280.31(c)]	✓		
	7	Lined tanks are inspected periodically and lining is in compliance. [280.21(b)(1)(ii)]	✓		
IV. Tank and Piping Corrosion Protection	8	Buried metal tank and piping (which includes fittings, connections, etc.) is corrosion protected. [280.20(a), 280.20(b), 280.21(b), 280.21(c)]		✓	
		<input type="checkbox"/> Buried metal piping components (such as swing joints, flex-connector, etc.) are isolated from the soil or cathodically protected. For new USTs - tanks and piping installed after 12/22/88 [280.20(a), 280.20(b)]: <input type="checkbox"/> Steel tank or piping is coated with suitable dielectric material and cathodically protected. [280.20(a)(2), 280.20(b)(2)] <input checked="" type="checkbox"/> Tank is fiberglass, clad, or jacketed and piping is fiberglass or flexible plastic. [280.20(a)(1), 280.20(a)(3), 280.20(a)(5), 280.20(b)(1), 280.20(b)(4)] <input type="checkbox"/> Records are available to document that CP is not necessary. [280.20(a)(4)(ii), 280.20(b)(3)(ii)] For existing USTs - tanks and piping installed on or before 12/22/88 [280.21(b), 280.21(c)]: <input type="checkbox"/> Tank and piping meet new UST requirements [280.21(a)(1)] <input type="checkbox"/> Steel tank is internally lined. [280.21 (b)] <input type="checkbox"/> Metal tank and piping are cathodically protected. [280.21(b)(2), 280.21(c)]			

Notes: N/A - Indicates that the measure is not applicable.

Any mark in the "N" (No) column means that the facility is not in Significant Operational Compliance (SOC) with Release Prevention Compliance Measures. In order for a compliance measure to be in SOC, all applicable check-box items must be in compliance.

Release Detection Compliance Measures Matrix

*Instructions - To Determine Compliance Status of Measures #1-7,
Work Through the Worksheet "Commonly Used Release Detection Methods" Below.*

Regulatory Subject Area	Measure #	SOC Measure/ Federal Citation	In Compliance?		
			N/A	Y	N
I. Release Detection Method Presence and Performance Requirements	1	Release detection method is present. [280.40(a)]			
	2	Release detection system is operating properly (i.e., able to detect a release from any portion of the system that routinely contains product). [(280.40(a)(1)]			
	3	Release detection system meets the performance standards at 280.43 or 280.44. [(280.40(a)(3)]			
	4	Implementing agency has been notified of suspected release as required. [(280.40(b)] <input type="checkbox"/> Non-passing results reported and resolved in accordance with implementing agency's directions. [280.40(b)]			
II. Release Detection Testing	5	Tanks and piping are monitored monthly for releases and records are available (must have records for the two most recent consecutive months and for 8 months of the last 12 months). [280.41(a), and 280.45(b)]			
III. Hazardous Substance UST Systems	6	Hazardous substance UST system leak detection meets the requirements (i.e., either secondarily contained or otherwise approved by the implementing agency). [280.42(b)]			
IV. Temporary Closure	7	Release detection requirements are complied with (i.e., method present, operational, releases investigated and reported as required) for UST systems containing product. [280.70(a)]			

Worksheet - Commonly Used Release Detection Methods

Tank (Choose one)	Pressurize d Pipe (Choose Two)	Non-exempt Suction Pipe (Choose one)	Release Detection Method
<input type="checkbox"/>			A. Inventory Control with Tank Tightness Testing (T.T.T) <input type="checkbox"/> Inventory control is conducted properly. <ul style="list-style-type: none"> <input type="checkbox"/> T.T.T. performed as required (See "D" below). <input type="checkbox"/> Inventory volume measurements for inputs, withdrawals, and remaining amounts are recorded each operating day and reconciled as required. [280.43(a)(1), 280.43(a)(3)] <input type="checkbox"/> Equipment is capable of 1/8-inch measurement. [280.43(a)(2)] <input type="checkbox"/> Product dispensing is metered and recorded within local standards for meter calibration to required accuracy. [280.43(a)(5)] <input type="checkbox"/> Water is monitored at least monthly. [280.43(a)(6)]

Release Detection Compliance Measures Matrix

Worksheet (Continued) - Commonly Used Release Detection Methods

Release Detection Method	Tank (Choose one)	Pressurize d Pipe (Choose Two)	Non-exempt Suction Pipe (Choose one)
B. Automatic Tank Gauge (ATG) <input type="checkbox"/> ATG is set up properly. [280.40(a)(2)] <input type="checkbox"/> ATG can detect a 0.2 gal/hr leak rate from any portion of the tank routinely containing product. [280.43(d)(1)] <input type="checkbox"/> ATG is checking portion of tank that routinely contains product. [280.40(a)(1)]	<input type="checkbox"/>		
C. Manual Tank Gauging (MTG) <input type="checkbox"/> Tank size is appropriate for using MTG. [280.43(b)(5)] <input type="checkbox"/> Tanks 1001 gals (as per EPA memo) and greater restricted to use with T.T.T. (See "D" below) Method is being conducted correctly. [280.43(b)(4)] <input type="checkbox"/> No liquid was added to or taken out of the tank during the test. [280.43(b)(1)] <input type="checkbox"/> Equipment is capable of 1/8-inch measurement. [280.43(b)(3)]	<input type="checkbox"/>		
D. Tightness Testing (Safe Suction piping does not require testing) <input type="checkbox"/> Testing method is capable of detecting a 0.1 gal/hr leak rate from any portion of tank routinely containing product. [280.43(c)] <input checked="" type="checkbox"/> Tightness testing is conducted within specified time frames for method: <input type="checkbox"/> Tanks - every 5 years [280.41(a)(1)] <input checked="" type="checkbox"/> Pressurized Piping - annually [280.41(b)(1)(ii)] <input type="checkbox"/> Non-exempt suction piping - every 3 years [280.41(b)(2)] <input type="checkbox"/> Tightness testing is conducted following manufacturer's instructions. [280.40(a)(3)]	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
E. Ground Water or Vapor Monitoring <input type="checkbox"/> Ground water in the monitoring well is never more than 20 feet from the ground surface. [280.43(f)(2)] <input type="checkbox"/> Vapor monitoring well is not affected by high ground water. [280.43(e)(3)] <input type="checkbox"/> Site assessment has been done for vapor or ground water monitoring. [280.43(e)(6), 280.43(f)(7)] <input type="checkbox"/> Wells are properly designed and positioned. [280.43(e)(6), 280.43(f)(7)]	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
F. Interstitial Monitoring <input type="checkbox"/> Secondary containment can be used to detect a release [280.43(g)(1)], [280.43(g)(2)] <input type="checkbox"/> Sensor properly positioned. [280.40(a)(2)]	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

3-290136

Release Detection Compliance Measures Matrix

Worksheet (Continued) - Commonly Used Release Detection Methods

Release Detection Method	Tank (Choose one)	Pressurize d Pipe (Choose Two)	Non-exempt Suction Pipe (Choose one)
	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>
G. Automatic Line Leak Detector (ALLD)			
<input checked="" type="checkbox"/> ALLD is present and operational. [280.44(a)]			
<input checked="" type="checkbox"/> Annual function test of the ALLD has been conducted and records are available. [280.44(a)]			
H. Other Methods [e.g., Statistical Inventory Reconciliation (S.I.R.)]	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input type="checkbox"/> The method can detect a 0.2 gal/hr leak rate or a release of 150 gal within a month and meet the 95/5 requirement [280.43(h)(1)]; or			
<input type="checkbox"/> The implementing agency has approved the method as being as effective as tank tightness testing, automatic tank gauging, vapor monitoring, ground water monitoring, or interstitial monitoring and the operator complies with any conditions imposed by agency. [280.43(h)(2)]			
<input checked="" type="checkbox"/> S.I.R. - Results are received within time frame established by implementing agency. [280.41(a) & 280.43(h)]			

Notes: N/A - Indicates that the measure is not applicable.

Any mark in the "N" (No) column means that the facility is not in Significant Operational Compliance (SOC) with Release Detection Compliance Measures.

In order for a compliance measure to be in SOC, all applicable check-box items must be in compliance.



Rockland County Department of Health
PETROLEUM BULK STORAGE APPLICATION

Pursuant to Petroleum Bulk Storage Law,
Article 10 of the Rockland County Sanitary Code
(Continued on the Reverse Side-Please be Sure to Complete Section B)

FACILITY SIZE AND FEE:

1,101 - 1,999 gallons \$145 / facility
2,000 - 10,000 gallons \$445 / facility
10,001 - 399,999 gallons \$710 / facility
Substantial Tank Modification \$180 / facility
New Tank Plan Review \$265 / plan
Return Completed Form, Fee and Site Plan to:
Rockland County Health Department
50 Sanatorium Road - Building D
Pomona, New York 10970

(845) 364-2605

PLEASE TYPE OR PRINT CLEARLY

Section A - See Instructions on Cover Sheet

PBS NUMBER 3-990136 Indicate other existing DEC Numbers, if any, for this facility: CBS Number: SPDES Number:	FACILITY NAME Getty #377 LOCATION (Not P.O. Boxes) 40 North main st. LOCATION (Continued) VILLAGE/HAMLET New City STATE NY ZIP CODE 10954 COUNTY ROCKLAND TOWNSHIP NAME OF OPERATOR AT FACILITY 40 N.M. CORP FACILITY TELEPHONE NUMBER (845) 639-8035 EMERGENCY CONTACT NAME LGA Ochotona EMERGENCY TELEPHONE NUMBER (800) 545-1235	TYPE OF PETROLEUM FACILITY: (Check all that apply) A. <input type="checkbox"/> Storage Terminal / Petroleum Distributor B. <input checked="" type="checkbox"/> Retail Gasoline Sales C. <input type="checkbox"/> Other Retail Sales D. <input type="checkbox"/> Manufacturing E. <input type="checkbox"/> Utility F. <input type="checkbox"/> Trucking / Transportation G. <input type="checkbox"/> Apartment Building H. <input type="checkbox"/> School I. <input type="checkbox"/> Farm J. <input type="checkbox"/> Private Residence K. <input type="checkbox"/> Airline (Air Taxi) L. <input type="checkbox"/> Other (Specify) I hereby certify under penalty of perjury that the information provided on this form is true to the best of my knowledge and belief. False statements made herein are punishable as a Class A misdemeanor pursuant to Section 210.45 of the Penal Law.
Geographical Locator for facility: TAX MAP: Section: _____ Block: _____ Lot: _____	OWNER NAME AOC Transport ADDRESS (Street and/or PO Box) 125 JERICHO TURNPIKE CITY JERICHO STATE NY ZIP CODE 11753 FEDERAL TAX ID NUMBER 80-0799499 OWNER TELEPHONE NUMBER (516) 478-5400 TYPE OF OWNER (Check only one) 1 <input type="checkbox"/> Private resident 2 <input type="checkbox"/> State Government 3 <input type="checkbox"/> Local Government 4 <input type="checkbox"/> Federal government 5 <input checked="" type="checkbox"/> Corporate/Commercial	NAME OF OWNER OR AUTHORIZED REPRESENTATIVE TITLE SIGNATURE _____ DATE _____
		ATTENTION JAMES CRAIG NAME OF COMPANY Getty Realty Corp. ADDRESS 125 Jericho Turnpike ADDRESS CITY/STATE/ZIP CODE JERICHO NY 11753 TELEPHONE NUMBER (516) 478-5400 E-MAIL ADDRESS FAX NUMBER ()

3-990136

Tank / Line Test Cover Page for Rockland County

PBS # 3-990136

TEST Date/Time: 3/10/2011

Due within 30 days

Report Sent Date: 3/21/2011

	Tank # 1	Line # 1	Tank # 2	Line # 2	Tank # 3	Line # 3	Tank #	Line #
(Circle)	Pass/Fail	Pass/Fail	Pass/Fail	Pass/Fail	Pass/Fail	Pass/Fail	Pass/Fail	Pass/Fail
	Log #	Log #	Log #	Log #	Log #	Log #	Log #	Log #
	11-084	11-085	11-086	11-087	11-088	11-089		
(if Failed)	DEC#	DEC#	DEC#	DEC#	DEC#	DEC#	DEC#	DEC#

Serial Numbers of Equipment Used (EZY-3)

Groundwater Level Inches: NA

Tank Bottom Level Inches: NA

Testers Name:

Steven Spadaro

Company Name:

Metro Environmental Services, LLC

Company Phone:

718-652-0200

**Submit To: Sandy Braun
Rockland County Dept. of Health
Yeager Health Center
Environmental Health Bldg. D
50 Sanatorium Road
Pomona, N.Y. 10970
(845) 364-2602**

Metro Environmental Services, LLC

4301 Boston Post Rd, Bronx, NY 10466

Phone# 718-652-0200 Fax# 718-652-0333

TIGHTNESS TEST COVER SHEET

Facility Getty # 377
Address 40 N. Main Street
New City, NY 10956

Date: 03/10/11

ID/PBS # 3-990136

Spill # 1012256

Tank Tests as of test date

PBS/ID #	Product	System	Rate	Pass/Fail	Log #	Notes
3	Regular	EZY 3 LP		Pass	11-084	
1	Mid-grade	EZY 3 LP		Pass	11-086	
3	Premium	EZY 3 LP		Fail	11-088	

Line Tests as of test date

Product	System	Rate	Pass/Fail	LD	Log #	Notes
Regular	EZ Chek		Pass	Pass	11-085	
Mid-grade	EZ Chek		Pass	Pass	11-087	
Premium	EZ Chek		Pass	Pass	11-089	

Vapor Testing as of test date

Test Performed	Pass/Fail	Test Performed	Pass/Fail	Notes
Pressure Decay		Six Click		
Dry Blockages		Healy Decay		
Wet Blockages		Healy Nozzle		
A/L Test		PV Cap Test		

Additional Tests as of test date

Test Performed	Pass/Fail	Notes
Shear Valves	Pass	
E.Stop Verification	Pass	
Overfill Verification	Pass	
Mini Audits	Pass	
Droptube Verification	Pass	

Misc Info: Compliance test. Premium tank failed due to bad motor gasket. Gasket needs to be replaced, resealed and re-tested

Technician: Steven Spadaro

Certs:

EZY 3LP & Chek # 72-14732 Exp 09/10

Petrotite #NYM0202041506C EXP 10/10

West.Co. # T00206 Exp 09/19/10

CT# 2911 Exp 06/11

Signature: 

15-780132

Metro Environmental Services, LLC

4301 Boston Post Rd, Bronx, NY 10466

Phone# 718-652-0200 Fax# 718-652-0333

Tank Test Final Report

EZY 3 LOCATOR PLUS - Vacuum Test			FINAL REPORT
DATE	<u>3/10/2011</u>	PBS #	<u>3-990136</u>
PBS TANK #	<u>1</u>	R.C. LOG #	<u>11-086</u>
TOTAL TANK VOL.	<u>6,000</u>	LOCATION	<u>Getty # 377</u>
PRODUCT VOL.	<u>973</u>		<u>40 N. Main Street</u>
ULLAGE VOL.	<u>5,027</u>		<u>New City, NY 10956</u>
PRODUCT TYPE	<u>Mid-grade</u>	SITE PHONE #	<u></u>
THE ACOUSTIC CHARACTERISTIC OF A LEAK REVEALS:			
<u>Pass</u>	TIGHT TANK AS OF TEST DATE This underground storage tank PASSES the criteria set forth by the U.S. E.P.A.		
	ULLAGE (DRY) PORTION LEAK This underground storage tank FAILS the criteria set forth by the U.S. E.P.A.		
	BELOW PRODUCT LEVEL (WET) PORTION LEAK This underground storage tank FAILS the criteria set forth by the U.S. E.P.A.		
WATER SENSOR INDICATES:			
NO H2O INTRUSION: <u></u>	H2O INTRUSION: <u>XXXX</u>	N/A: <u></u>	
EZY #3 LOCATOR PLUS EQUIPMENT INFO			
Equipment	Serial #'s	Calibration Due Date	
Acoustic Signal Processor	<u>E213016</u>	<u>8/30/2011</u>	
In Tank Microphone	<u>M1006007</u>	<u>8/30/2011</u>	
Pressure Sensor	<u>65250706</u>	<u>8/30/2011</u>	
Water Probe	<u>NA</u>	<u>NA</u>	
Water Sensor Display	<u>NA</u>	<u>NA</u>	
OPERATOR INFORMATION:			
PRINT NAME:	<u>Steven Spadaro</u>	CERTIFICATION #'s:	<u>EZY 3LP & Chek # 72-14732 Exp 09/10</u>
			<u>Petrotite #NYM0202041506C EXP 10/10</u>
			<u>West Co. # T00206 Exp 09/19/10</u>
			<u>CT# 2911 Exp 06/11</u>
SIGN NAME:	<u></u>		<u></u>

MENTAL SERVICES, LLC

466 Phone# 718-652-0200 Fax# 718-652-0333

EZY 3 LOCATOR PLUS

PRESSURE CALCULATION & WATER SENSOR CALIBRATION

DATE 3-10-11
 TOTAL TANK VOL. 6,000
 PRODUCT VOL. 975
 ULLAGE VOL. 5,025
 PRODUCT TYPE PLS
 Tech Sign: [Signature]

PBS# (NEW YORK) 3-990135
 TANK # 21 Les# 11-085
 LOCATION Goth #375
40 W North Main St.
New City NY 10956
 Certifications: EZY 3 LP # 72-4732


PRESSURE SENSOR CALCULATION

21 X 1.026 = .55 0.00 PSI (1)
 INCHES of PRODUCT WEIGHT of PRODUCT
0 X 0.036 = 0 0.00 PSI (2)
 INCHES of WATER in TANK
 Line 1 + Line 2 = Total Positive Head Pressure In Tank = .55 0.00 PSI (3)
0 X 0.036 = 0 0.00 PSI (4)
 INCHES of WATER OUTSIDE TANK
 Total Head Pressure Minus Outside Water Pressure = .55 0.00 +/- PSI (5)
 Always add .5 PSI + .50 PSI (6)
 NOTE: If Line 6 is Less than .5 PSI, Line 7 shall be .5 PSI
 TEST PRESSURE = 1.05 +/- PSI (7)

	TIME	PRESSURE	Equipment S/N	Calibration Due
Blower Started:	<u>1018</u>	<u>0</u>	Amplifier <u>ED12006</u>	<u>8-30-11</u>
Test Pressure Reached:	<u>1025</u>	<u>1.05</u>	Mic <u>M10006-7</u>	<u>8-30-11</u>
Blower Turned Off:	<u>1035</u>	<u>1.10</u>	Digital Gauge <u>68230766</u>	<u>8-30-11</u>
Test Began:	<u>1038</u>	<u>1.10</u>	Water Sensor <u>N/A</u>	
Test Ended:	<u>1040</u>	<u>1.10</u>	Water Display <u>N/A</u>	
Depth of Groundwater Determined by <u>Interstital</u>				
Where: <u>Tank Top</u>				
System test			<u>Y</u> <u>Pass/Fail</u>	

WATER SENSOR CALIBRATION

Acc'd: Cal # 1 Cal # 2 Cal # 3
 Average: [Signature]
 Water Intrusion Test Method: Began
 Calculation for Test Period:
 Ave. Cal. 3780 = -.06 X 60 = Min Time of test



Metro Environmental Services, LLC

4301 Boston Post Rd, Bronx, NY 10466

Phone# 718-652-0200 Fax# 718-652-0333

Tank Test Final Report

EZY 3 LOCATOR PLUS - Vacuum Test		FINAL REPORT	
DATE	<u>3/10/2011</u>	PBS #	<u>3-990136</u>
PBS TANK #	<u>2</u>	R.C. LOG #	<u>11-088</u>
TOTAL TANK VOL.	<u>8,000</u>	LOCATION	<u>Getty # 377</u>
PRODUCT VOL.	<u>579</u>		<u>40 N. Main Street</u>
ULLAGE VOL.	<u>7,421</u>		<u>New City, NY 10956</u>
PRODUCT TYPE	<u>Premium</u>	SITE PHONE #	<u></u>
THE ACOUSTIC CHARACTERISTIC OF A LEAK REVEALS:			
TIGHT TANK AS OF TEST DATE			
	This underground storage tank PASSES the criteria set forth by the U.S. E.P.A.		
Fail	ULLAGE (DRY) PORTION LEAK		
	This underground storage tank FAILS the criteria set forth by the U.S. E.P.A.		
	BELOW PRODUCT LEVEL (WET) PORTION LEAK		
	This underground storage tank FAILS the criteria set forth by the U.S. E.P.A.		
WATER SENSOR INDICATES:			
NO H2O INTRUSION: <u></u>	H2O INTRUSION: <u>XXXX</u>	N/A: <u></u>	
EZY #3 LOCATOR PLUS EQUIPMENT INFO			
Equipment	Serial #'s	Calibration Due Date	
Acoustic Signal Processor	<u>E213016</u>	<u>8/30/2011</u>	
In Tank Microphone	<u>M15010</u>	<u>8/30/2011</u>	
Pressure Sensor	<u>65250706</u>	<u>8/30/2011</u>	
Water Probe	<u>NA</u>	<u>NA</u>	
Water Sensor Display	<u>NA</u>	<u>NA</u>	
OPERATOR INFORMATION:			
PRINT NAME:	<u>Steven Spadaro</u>	CERTIFICATION #'s:	<u>EZY 3LP & Chek # 72-14732 Exp 09/10</u>
			<u>Petrotite #NYM0202041506C EXP 10/10</u>
			<u>West.Co. # T00206 Exp 09/19/10</u>
			<u>CT# 2911 Exp 06/11</u>
SIGN NAME:	<u></u>		<u></u>

MENTAL SERVICES, LLC

466 Phone# 718-652-0200 Fax# 718-652-0333

EZY 3 LOCATOR PLUS

PRESSURE CALCULATION & WATER SENSOR CALIBRATION

DATE 3-10-11
 TOTAL TANK VOL ~~8000~~ 10,000
 PRODUCT VOL 4213
 ULLAGE VOL 5782
 PRODUCT TYPE Regular
 Tech Sign [Signature]

PBS# (NEW YORK) 3-990136
 TANK # 3 11-059
 LOCATION Gett # 327
40 W Main St.
New City NY 10956
 Certifications: EZY 3 LP # 72-4732

PRESSURE SENSOR CALCULATION


42 X 0.025 = 1.09 0.00 PSI (1)
 INCHES of PRODUCT WEIGHT of PRODUCT
0 X 0.036 = 0 0.00 PSI (2)
 INCHES of WATER in TANK
 Line 1 + Line 2 = Total Positive Head Pressure In Tank = 1.09 0.00 PSI (3)
0 X 0.036 = 0 0.00 PSI (4)
 INCHES of WATER OUTSIDE TANK
 Total Head Pressure Minus Outside Water Pressure = 1.09 0.00 +/- PSI (5)
 Always add .5 PSI + .50 PSI (6)
 NOTE: If Line 6 is Less than .5 PSI, Line 7 shall be .5 PSI
 TEST PRESSURE = 1.59 +/- PSI (7)

	TIME	PRESSURE	Equipment S/N	Calibration Due
Blower Started:	<u>11:50</u>	<u>0</u>	Amplifier <u>E213016</u>	<u>8-30-11</u>
Test Pressure Reached:	<u>12:00</u>	<u>1.59</u>	Mic <u>M15010</u>	<u>8-30-11</u>
Blower Turned Off:	<u>12:10</u>	<u>1.59</u>	Digital Gauge <u>55250726</u>	<u>8-30-11</u>
Test Began:	<u>12:10</u>	<u>1.59</u>	Water Sensor <u>N/A</u>	
Test Ended:	<u>12:15</u>	<u>1.59</u>	Water Display <u>N/A</u>	

Depth of Groundwater Determined by: Interstate 1
 Where: Tank Top
 System test YR Pass/Fail

WATER SENSOR CALIBRATION

Added Test Error
 Cal # 1 2.10 Cal # 2 1.87 Cal # 3 1.87
 Average 1.95
 Water Intrusion Test Period 1.95
 Calculation for Test Period:
 Ave. Cal. 1.95 X 60 = 117
 "A" Factor 1 Min Time of test 117



3-990136

Metro Environmental Services, LLC

4301 Boston Post Rd, Bronx, NY 10466

Phone# 718-652-0200 Fax# 718-652-0333

Tank Test Final Report

EZY 3 LOCATOR PLUS - Vacuum Test		FINAL REPORT	
DATE	<u>3/10/2011</u>	PBS #	<u>3-990136</u>
PBS TANK #	<u>3</u>	R.C. LOG #	<u>11-084</u>
TOTAL TANK VOL.	<u>10,000</u>	LOCATION	<u>Getty # 377</u>
PRODUCT VOL.	<u>4,218</u>		<u>40 N. Main Street</u>
ULLAGE VOL.	<u>5,782</u>		<u>New City, NY 10956</u>
PRODUCT TYPE	<u>Regular</u>	SITE PHONE #	<u></u>
THE ACOUSTIC CHARACTERISTIC OF A LEAK REVEALS:			
<u>Pass</u>	TIGHT TANK AS OF TEST DATE This underground storage tank PASSES the criteria set forth by the U.S. E.P.A.		
	ULLAGE (DRY) PORTION LEAK This underground storage tank FAILS the criteria set forth by the U.S. E.P.A.		
	BELOW PRODUCT LEVEL (WET) PORTION LEAK This underground storage tank FAILS the criteria set forth by the U.S. E.P.A.		
WATER SENSOR INDICATES:			
NO H2O INTRUSION: <u></u>	H2O INTRUSION: <u>XXXX</u>	N/A: <u></u>	
EZY #3 LOCATOR PLUS EQUIPMENT INFO			
Equipment	Serial #'s	Calibration Due Date	
Acoustic Signal Processor	<u>E213016</u>	<u>8/30/2011</u>	
In Tank Microphone	<u>M15010</u>	<u>8/30/2011</u>	
Pressure Sensor	<u>65250706</u>	<u>8/30/2011</u>	
Water Probe	<u>NA</u>	<u>NA</u>	
Water Sensor Display	<u>NA</u>	<u>NA</u>	
OPERATOR INFORMATION:			
PRINT NAME: <u>Steven Spadaro</u>	CERTIFICATION #'s: <u>EZY 3LP & Chek # 72-14732 Exp 09/10</u>		
	<u>Petrotite #NYM0202041506C EXP 10/10</u>		
	<u>West Co. # T00206 Exp 09/19/10</u>		
	<u>CT# 2911 Exp 06/11</u>		
SIGN NAME: <u></u>	<u></u>		

MENTAL SERVICES, LLC

466 Phone# 718-652-0200 Fax# 718-652-0333

EZY 3 LOCATOR PLUS

PRESSURE CALCULATION & WATER SENSOR CALIBRATION

DATE 3-19-11
 TOTAL TANK VOL. 8,000
 PRODUCT VOL. 579
 ULLAGE VOL. 7421
 PRODUCT TYPE Premium

PBS# (NEW YORK) 3-990136
 TANK # 2 Lot # 11-083
 LOCATION 6411 # 322
40 W Main St.
NEW CITY NY 10956

Tech Sign [Signature]

Certifications: EZY 3 LP # 72-4732


PRESSURE SENSOR CALCULATION

12 X 1.25 = .31 0.00 PSI (1)
 INCHES of PRODUCT WEIGHT of PRODUCT
0 X 0.036 = 0 0.00 PSI (2)
 INCHES of WATER in TANK
 Line 1 + Line 2 = Total Positive Head Pressure in Tank = .31 0.00 PSI (3)
0 X 0.036 = 0 0.00 PSI (4)
 INCHES of WATER OUTSIDE TANK
 Total Head Pressure Minus Outside Water Pressure = .31 0.00 +/- PSI (5)
 Always add .5 PSI + .50 PSI (6)
 NOTE: If Line 6 is Less than .5 PSI, Line 7 shall be .5 PSI
 TEST PRESSURE = .81 +/- PSI (7)

	TIME	PRESSURE	Equipment S/N	Calibration Due
Blower Started:	<u>10:18</u>	<u>0</u>	Amplifier <u>E11116</u>	<u>8-30-11</u>
Test Pressure Reached:	<u>10:21</u>	<u>.81</u>	Mic <u>M13010</u>	<u>8-30-11</u>
Blower Turned Off:	<u>10:35</u>	<u>.90</u>	Digital Gauge <u>63287206</u>	<u>8-30-11</u>
Test Began:	<u>10:41</u>	<u>.83</u>	Water Sensor <u>N/A</u>	
Test Ended:	<u>10:45</u>	<u>.74</u>	Water Display <u>N/A</u>	
Depth of Groundwater Determined by: <u>Inter-Amb</u>				
Where: <u>Tank Top</u>				
System test			<u>YES</u> <u>NO</u> <u>Fail</u>	

WATER SENSOR CALIBRATION

Added: Ca. # 1 Ca. # 2 Ca. # 3
 Average: [Handwritten]
 Water intrusion Test Period: [Handwritten]
 Calculation for Test Period: Sum # 101.2256
 Ave. Cal. 3780 0.05 X 60 = [Handwritten]
 Ave. Cal. "A" Factor [Handwritten] Time of test [Handwritten]



Metro Environmental Services, LLC
4301 Boston Post Rd, Bronx, NY 10466
Phone # 718-652-0200 Fax # 718-652-0333

Line and Leak Detector Test Results

Station: Getty # 377 **Date:** 08/31/11
Address: 40 North Main Street
New City, NY **ID/PBS #:** 3-990136

Product Line Tests

Product #1	Regular	Product #2		Product #3		Product #4	
Test Psi:	50	Test Psi:		Test Psi:		Test Psi:	
Start Time:	12:30 PM	Start Time:		Start Time:		Start Time:	
1st level (gph):	0.0148	1st level (gph):		1st level (gph):		1st level (gph):	
2nd Level (gph):	0.0000	2nd Level (gph):		2nd Level (gph):		2nd Level (gph):	
Final Level (gph):	0.0148	Final Level (gph):		Final Level (gph):		Final Level (gph):	
End Time:	2:30 PM	End Time:		End Time:		End Time:	
Duration (min.):	120	Duration (min.):	45	Duration (min.):	45	Duration (min.):	45
Leak Rate (gph):	0.0099	Leak Rate (gph):	0.0000	Leak Rate (gph):	0.0000	Leak Rate (gph):	0.0000
Results:	Pass	Results:		Results:		Results:	

Leak Detector Tests

LD Make:		LD Make:		LD Make:		LD Make:	
LD Model:		LD Model:		LD Model:		LD Model:	
LD Serial#:		LD Serial#:		LD Serial#:		LD Serial#:	
Leak Rate (gph):	3.0	Leak Rate (gph):	3.0	Leak Rate (gph):	3.0	Leak Rate (gph):	3.0
Operating Psi:		Operating Psi:		Operating Psi:		Operating Psi:	
Holding Psi:		Holding Psi:		Holding Psi:		Holding Psi:	
Resiliency (ml):		Resiliency (ml):		Resiliency (ml):		Resiliency (ml):	
Open Time (sec.):		Open Time (sec.):		Open Time (sec.):		Open Time (sec.):	
LD Results:		LD Results:		LD Results:		LD Results:	

Replacment Leak Detector Tests

New LD Make:		New LD Make:		New LD Make:		New LD Make:	
New LD Model:		New LD Model:		New LD Model:		New LD Model:	
New LD Serial#:		New LD Serial#:		New LD Serial#:		New LD Serial#:	
New LD Results:		New LD Results:		New LD Results:		New LD Results:	

Technician: Steven Spadaro

Certifications: EZY 3LP & Chek # 72-14732 Exp 09/10

Petrolite #NYM0202041506C EXP 10/10

West.Co. # T00206 Exp 09/19/10

CT# 2911 Exp 06/11

Signature: _____

ENCLOSURE

TEST SITE: Gettysburg #377
ADDRESS: 40 N Main St
New City, NY
TEST DATE: 2-31-11
PBS: 3-4990136
TECH NAME & CERT #: Steven Spadaro Lic. # 72-14732
TECH SIGNATURE: [Signature]

TECH SIGNATURE:

[illegible]

3-990136

Metro Environmental Services, LLC

4301 Boston Post Rd, Bronx, NY 10466

Phone# 718-652-0200 Fax# 718-652-0333

TIGHTNESS TEST COVER SHEETFacility
Address

Getty # 377

40 N. Main Street

New City, NY 10956

Date: 03/10/11

ID/PBS # 3-990136

Spill # 1012256

Tank Tests as of test date

PBS/ID #	Product	System	Rate	Pass/Fail	Log #	Notes
3	Regular	EZY 3 LP		Pass	11-084	
1	Mid-grade	EZY 3 LP		Pass	11-086	
3	Premium	EZY 3 LP		Fail	11-088	

Line Tests as of test date

Product	System	Rate	Pass/Fail	LD	Log #	Notes
Regular	EZ Chek		Pass	Pass	11-085	
Mid-grade	EZ Chek		Pass	Pass	11-087	
Premium	EZ Chek		Pass	Pass	11-089	

Vapor Testing as of test date

Test Performed	Pass/Fail	Test Performed	Pass/Fail	Notes
Pressure Decay		Six Click		
Dry Blockages		Healy Decay		
Wet Blockages		Healy Nozzle		
A/L Test		PV Cap Test		

Additional Tests as of test date

Test Performed	Pass/Fail	Notes
Shear Valves	Pass	
E.Stop Verification	Pass	
Overfill Verification	Pass	
Mini Audits	Pass	
Droptube Verification	Pass	

Misc Info: Compliance test. Premium tank failed due to bad motor gasket. Gasket needs to be replaced, resealed and re-tested

Technician: Steven Spadaro

Certs:

EZY 3LP & Chek # 72-14732 Exp 09/10

Petroline #NYM0202041506C EXP 10/10

West Co. # T00206 Exp 09/19/10

CT# 2911 Exp 06/11

Signature:

Metro Environmental Services, LLC
4301 Boston Post Rd, Bronx, NY 10466
Phone # 718-652-0200 Fax # 718-652-0333

Line and Leak Detector Test Results

Station: Getty # 377 **Date:** 03/10/11
Address: 40 N. Main Street
New City, NY 10956 **ID/PBS #:** 3-990136

Product Line Tests

Product #1	Regular	Product #2	Mid-grade	Product #3	Premium	Product #4	
Test Psi:	50	Test Psi:	50	Test Psi:	50	Test Psi:	
Start Time:	9:15 AM	Start Time:	9:15 AM	Start Time:	9:15 AM	Start Time:	
1st level (gph):	0.0000	1st level (gph):	0.0000	1st level (gph):	0.0000	1st level (gph):	
2nd Level (gph):	0.0000	2nd Level (gph):	0.0000	2nd Level (gph):	0.0000	2nd Level (gph):	
Final Level (gph):	0.0000	Final Level (gph):	0.0000	Final Level (gph):	0.0000	Final Level (gph):	
End Time:	11:15 AM	End Time:	11:15 AM	End Time:	11:15 AM	End Time:	
Duration (min.):	120	Duration (min.):	120	Duration (min.):	120	Duration (min.):	45
Leak Rate (gph):	0.0000	Leak Rate (gph):	0.0000	Leak Rate (gph):	0.0000	Leak Rate (gph):	0.0000
Results:	Pass	Results:	Pass	Results:	Pass	Results:	

Leak Detector Tests

LD Make:	Red Jacket	LD Make:	FePEtro	LD Make:	Red Jacket	LD Make:	
LD Model:	FX1V	LD Model:	STPMLD	LD Model:	FX1V	LD Model:	
LD Serial#:	100254887	LD Serial#:	04030133	LD Serial#:	05021602	LD Serial#:	
Leak Rate (gph):	3.0	Leak Rate (gph):	3.0	Leak Rate (gph):	3.0	Leak Rate (gph):	3.0
Operating Psi:	30	Operating Psi:	25	Operating Psi:	27	Operating Psi:	
Holding Psi:	28	Holding Psi:	15	Holding Psi:	12	Holding Psi:	
Resiliency (ml):	110	Resiliency (ml):	200	Resiliency (ml):	130	Resiliency (ml):	
Open Time (sec.):	2.0	Open Time (sec.):	2.0	Open Time (sec.):	4.0	Open Time (sec.):	
LD Results:	Pass	LD Results:	Pass	LD Results:	Pass	LD Results:	

Replacment Leak Detector Tests

New LD Make:		New LD Make:		New LD Make:		New LD Make:	
New LD Model:		New LD Model:		New LD Model:		New LD Model:	
New LD Serial#:		New LD Serial#:		New LD Serial#:		New LD Serial#:	
New LD Results:		New LD Results:		New LD Results:		New LD Results:	

Technician: Steven Spadaro

Certifications: EZY 3LP & Chek # 72-14732 Exp 09/10

Petrotite #NYM0202041506C EXP 10/10

West.Co. # T00206 Exp 09/19/10

CT# 2911 Exp 06/11

Signature: _____

WARREN ROGERS ASSOCIATES, INC.
747 AQUIDNECK AVENUE, MIDDLETOWN, RHODE ISLAND 02842
1-800-WRA-SIRA

MONTHLY STATISTICAL INVENTORY RECONCILIATION (SIR) REPORT

03/18/2013

TANK OWNER	GETTY REALTY CORP.
	125 JERICO TPKE.
	JERICO, NY 11753
FACILITY NAME	GETTY REALTY CORP. - 00377 - 00377
TANK LOCATION	40 NORTH MAIN STREET
	NEW CITY, NY 10956

Tank ID- Product	Tank Capacity	Period Covered	Threshold	Minimum Detectable Leak Rate	Measured Leak Rate	System Status Pass, Fail Inconclusive	Monitoring Standards/Cause
	gallons		gph	gph	gph	P,F,I	
1 -R	10000	01/29/2013-02/28/2013	0.005	0.010	0.00	P	NO LOSS-LOW THROUGHPUT OR DORMANT TANK
2 -S	8000	01/29/2013-02/28/2013	0.005	0.010	0.00	P	NO LOSS-LOW THROUGHPUT OR DORMANT TANK
3 -P	6000	01/29/2013-02/28/2013	0.005	0.010	0.00	P	NO LOSS-LOW THROUGHPUT OR DORMANT TANK

Keep this report on file for at least one year.

WRA SIRA® TANK REPORT – 03/18/2013

WRA ID : 90637
 LOCATION : 00377
 TANK ID : 1
 PRODUCT : R

PERIOD : 01/29/2013-02/28/2013
 SYSTEM CAPACITY : 10000
 MDL : 0.010
 LEAK RATE : 0.00

EVIDENCE OF POSSIBLE LEAKAGE

Our analysis of your inventory records for this tank shows NO evidence of leakage. We have assumed that stick readings were taken (either manually or by an automatic tank gauge) on all days submitted (including days of no activity). Conclusions presented as to the presence or absence of leakage therefore depend on that assumption.

DATE	SALES	DELIVERIES	STICK READING	INCH1	INCH2	DAILY OVER/SHORT	CUMULATIVE OVER/SHORT
01/29/13	0.0	0.0	32.0	1.500	0.000	0.0	0.0
01/30/13	0.0	0.0	32.0	1.500	0.000	0.0	0.0
01/31/13	0.0	0.0	32.0	1.500	0.000	0.0	0.0
02/01/13	0.0	0.0	32.0	1.500	0.000	0.0	0.0
02/02/13	0.0	0.0	32.0	1.500	0.000	0.0	0.0
02/03/13	0.0	0.0	32.0	1.500	0.000	0.0	0.0
02/04/13	0.0	0.0	32.0	1.500	0.000	0.0	0.0
02/05/13	0.0	0.0	32.0	1.500	0.000	0.0	0.0
02/06/13	0.0	0.0	32.0	1.500	0.000	0.0	0.0
02/07/13	0.0	0.0	32.0	1.500	0.000	0.0	0.0
02/08/13	0.0	0.0	32.0	1.500	0.000	0.0	0.0
02/09/13	0.0	0.0	32.0	1.500	0.000	0.0	0.0
02/10/13	0.0	0.0	32.0	1.500	0.000	0.0	0.0
02/11/13	0.0	0.0	32.0	1.500	0.000	0.0	0.0
02/12/13	0.0	0.0	32.0	1.500	0.000	0.0	0.0
02/13/13	0.0	0.0	32.0	1.500	0.000	0.0	0.0
02/14/13	0.0	0.0	32.0	1.500	0.000	0.0	0.0
02/15/13	0.0	0.0	32.0	1.500	0.000	0.0	0.0
02/16/13	0.0	0.0	32.0	1.500	0.000	0.0	0.0
02/17/13	0.0	0.0	32.0	1.500	0.000	0.0	0.0
02/18/13	0.0	0.0	32.0	1.500	0.000	0.0	0.0
02/19/13	0.0	0.0	32.0	1.500	0.000	0.0	0.0
02/20/13	0.0	0.0	32.0	1.500	0.000	0.0	0.0
02/21/13	0.0	0.0	32.0	1.500	0.000	0.0	0.0
02/22/13	0.0	0.0	32.0	1.500	0.000	0.0	0.0
02/23/13	0.0	0.0	32.0	1.500	0.000	0.0	0.0
02/24/13	0.0	0.0	32.0	1.500	0.000	0.0	0.0
02/25/13	0.0	0.0	32.0	1.500	0.000	0.0	0.0
02/26/13	0.0	0.0	32.0	1.500	0.000	0.0	0.0
02/27/13	0.0	0.0	32.0	1.500	0.000	0.0	0.0
02/28/13	0.0	0.0	32.0	1.500	0.000	0.0	0.0

3-9701-2

WRA SIRA® TANK REPORT – 03/18/2013

WRA ID : 90637
LOCATION : 00377
TANK ID : 2
PRODUCT : S

PERIOD : 01/29/2013-02/28/2013
SYSTEM CAPACITY : 8000
MDL : 0.010
LEAK RATE : 0.00

EVIDENCE OF POSSIBLE LEAKAGE

Our analysis of your inventory records for this tank shows NO evidence of leakage. We have assumed that stick readings were taken (either manually or by an automatic tank gauge) on all days submitted (including days of no activity). Conclusions presented as to the presence or absence of leakage therefore depend on that assumption.

DATE	SALES	DELIVERIES	STICK READING	INCH1	INCH2	DAILY OVER/SHORT	CUMULATIVE OVER/SHORT
01/29/13	0.0	0.0	35.0	1.875	0.000	0.0	0.0
01/30/13	0.0	0.0	35.0	1.875	0.000	0.0	0.0
01/31/13	0.0	0.0	35.0	1.875	0.000	0.0	0.0
02/01/13	0.0	0.0	35.0	1.875	0.000	0.0	0.0
02/02/13	0.0	0.0	35.0	1.875	0.000	0.0	0.0
02/03/13	0.0	0.0	35.0	1.875	0.000	0.0	0.0
02/04/13	0.0	0.0	35.0	1.875	0.000	0.0	0.0
02/05/13	0.0	0.0	35.0	1.875	0.000	0.0	0.0
02/06/13	0.0	0.0	35.0	1.875	0.000	0.0	0.0
02/07/13	0.0	0.0	35.0	1.875	0.000	0.0	0.0
02/08/13	0.0	0.0	35.0	1.875	0.000	0.0	0.0
02/09/13	0.0	0.0	35.0	1.875	0.000	0.0	0.0
02/10/13	0.0	0.0	35.0	1.875	0.000	0.0	0.0
02/11/13	0.0	0.0	35.0	1.875	0.000	0.0	0.0
02/12/13	0.0	0.0	35.0	1.875	0.000	0.0	0.0
02/13/13	0.0	0.0	35.0	1.875	0.000	0.0	0.0
02/14/13	0.0	0.0	35.0	1.875	0.000	0.0	0.0
02/15/13	0.0	0.0	35.0	1.875	0.000	0.0	0.0
02/16/13	0.0	0.0	35.0	1.875	0.000	0.0	0.0
02/17/13	0.0	0.0	35.0	1.875	0.000	0.0	0.0
02/18/13	0.0	0.0	35.0	1.875	0.000	0.0	0.0
02/19/13	0.0	0.0	35.0	1.875	0.000	0.0	0.0
02/20/13	0.0	0.0	35.0	1.875	0.000	0.0	0.0
02/21/13	0.0	0.0	35.0	1.875	0.000	0.0	0.0
02/22/13	0.0	0.0	35.0	1.875	0.000	0.0	0.0
02/23/13	0.0	0.0	35.0	1.875	0.000	0.0	0.0
02/24/13	0.0	0.0	35.0	1.875	0.000	0.0	0.0
02/25/13	0.0	0.0	35.0	1.875	0.000	0.0	0.0
02/26/13	0.0	0.0	35.0	1.875	0.000	0.0	0.0
02/27/13	0.0	0.0	35.0	1.875	0.000	0.0	0.0
02/28/13	0.0	0.0	35.0	1.875	0.000	0.0	0.0

WRA SIRA® TANK REPORT – 03/18/2013

WRA ID : 90637
LOCATION : 00377
TANK ID : 3
PRODUCT : P

PERIOD : 01/29/2013-02/28/2013
SYSTEM CAPACITY : 6000
MDL : 0.010
LEAK RATE : 0.00

EVIDENCE OF POSSIBLE LEAKAGE

Our analysis of your inventory records for this tank shows NO evidence of leakage. We have assumed that stick readings were taken (either manually or by an automatic tank gauge) on all days submitted (including days of no activity). Conclusions presented as to the presence or absence of leakage therefore depend on that assumption.

<u>DATE</u>	<u>SALES</u>	<u>DELIVERIES</u>	<u>STICK READING</u>	<u>INCH1</u>	<u>INCH2</u>	<u>DAILY OVER/SHORT</u>	<u>CUMULATIVE OVER/SHORT</u>
01/29/13	0.0	0.0	49.1	3.000	0.000	0.0	0.0
01/30/13	0.0	0.0	49.1	3.000	0.000	0.0	0.0
01/31/13	0.0	0.0	49.1	3.000	0.000	0.0	0.0
02/01/13	0.0	0.0	49.1	3.000	0.000	0.0	0.0
02/02/13	0.0	0.0	49.1	3.000	0.000	0.0	0.0
02/03/13	0.0	0.0	49.1	3.000	0.000	0.0	0.0
02/04/13	0.0	0.0	49.1	3.000	0.000	0.0	0.0
02/05/13	0.0	0.0	49.1	3.000	0.000	0.0	0.0
02/06/13	0.0	0.0	49.1	3.000	0.000	0.0	0.0
02/07/13	0.0	0.0	49.1	3.000	0.000	0.0	0.0
02/08/13	0.0	0.0	49.1	3.000	0.000	0.0	0.0
02/09/13	0.0	0.0	49.1	3.000	0.000	0.0	0.0
02/10/13	0.0	0.0	49.1	3.000	0.000	0.0	0.0
02/11/13	0.0	0.0	49.1	3.000	0.000	0.0	0.0
02/12/13	0.0	0.0	49.1	3.000	0.000	0.0	0.0
02/13/13	0.0	0.0	49.1	3.000	0.000	0.0	0.0
02/14/13	0.0	0.0	49.1	3.000	0.000	0.0	0.0
02/15/13	0.0	0.0	49.1	3.000	0.000	0.0	0.0
02/16/13	0.0	0.0	49.1	3.000	0.000	0.0	0.0
02/17/13	0.0	0.0	49.1	3.000	0.000	0.0	0.0
02/18/13	0.0	0.0	49.1	3.000	0.000	0.0	0.0
02/19/13	0.0	0.0	49.1	3.000	0.000	0.0	0.0
02/20/13	0.0	0.0	49.1	3.000	0.000	0.0	0.0
02/21/13	0.0	0.0	49.1	3.000	0.000	0.0	0.0
02/22/13	0.0	0.0	49.1	3.000	0.000	0.0	0.0
02/23/13	0.0	0.0	49.1	3.000	0.000	0.0	0.0
02/24/13	0.0	0.0	49.1	3.000	0.000	0.0	0.0
02/25/13	0.0	0.0	49.1	3.000	0.000	0.0	0.0
02/26/13	0.0	0.0	49.1	3.000	0.000	0.0	0.0
02/27/13	0.0	0.0	49.1	3.000	0.000	0.0	0.0
02/28/13	0.0	0.0	49.1	3.000	0.000	0.0	0.0

3-990130

WARREN ROGERS ASSOCIATES, INC.
747 AQUIDNECK AVENUE, MIDDLETOWN, RHODE ISLAND 02842
1-800-WRA-SIRA

MONTHLY STATISTICAL INVENTORY RECONCILIATION (SIR) REPORT

03/18/2013

TANK OWNER	GETTY REALTY CORP.
	125 JERICHO TPKE.
	JERICHO, NY 11753
FACILITY NAME	GETTY REALTY CORP. - 00377 - 00377
TANK LOCATION	40 NORTH MAIN STREET
	NEW CITY, NY 10956

Tank ID- Product	Tank Capacity	Period Covered	Threshold	Minimum Detectable Leak Rate	Measured Leak Rate	System Status Pass, Fail Inconclusive	Monitoring Standards/Cause
	gallons		gph	gph	gph	P,F,I	
1 -R	10000	12/29/2012-01/28/2013	0.005	0.010	0.00	P	NO LOSS-LOW THROUGHPUT OR DORMANT TANK
2 -S	8000	12/29/2012-01/28/2013	0.005	0.010	0.00	P	NO LOSS-LOW THROUGHPUT OR DORMANT TANK
3 -P	6000	12/29/2012-01/28/2013	0.005	0.010	0.00	P	NO LOSS-LOW THROUGHPUT OR DORMANT TANK

Keep this report on file for at least one year.

WRA SIRA® TANK REPORT – 03/18/2013

WRA ID : 90637
LOCATION : 00377
TANK ID : 1
PRODUCT : R

PERIOD : 12/29/2012-01/28/2013
SYSTEM CAPACITY : 10000
MDL : 0.010
LEAK RATE : 0.00

EVIDENCE OF POSSIBLE LEAKAGE

Our analysis of your inventory records for this tank shows NO evidence of leakage. We have assumed that stick readings were taken (either manually or by an automatic tank gauge) on all days submitted (including days of no activity). Conclusions presented as to the presence or absence of leakage therefore depend on that assumption.

<u>DATE</u>	<u>SALES</u>	<u>DELIVERIES</u>	<u>STICK READING</u>	<u>INCH1</u>	<u>INCH2</u>	<u>DAILY OVER/SHORT</u>	<u>CUMULATIVE OVER/SHORT</u>
12/29/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
12/30/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
12/31/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
01/01/13	0.0	0.0	32.0	1.500	0.000	0.0	0.0
01/02/13	0.0	0.0	32.0	1.500	0.000	0.0	0.0
01/03/13	0.0	0.0	32.0	1.500	0.000	0.0	0.0
01/04/13	0.0	0.0	32.0	1.500	0.000	0.0	0.0
01/05/13	0.0	0.0	32.0	1.500	0.000	0.0	0.0
01/06/13	0.0	0.0	32.0	1.500	0.000	0.0	0.0
01/07/13	0.0	0.0	32.0	1.500	0.000	0.0	0.0
01/08/13	0.0	0.0	32.0	1.500	0.000	0.0	0.0
01/09/13	0.0	0.0	32.0	1.500	0.000	0.0	0.0
01/10/13	0.0	0.0	32.0	1.500	0.000	0.0	0.0
01/11/13	0.0	0.0	32.0	1.500	0.000	0.0	0.0
01/12/13	0.0	0.0	32.0	1.500	0.000	0.0	0.0
01/13/13	0.0	0.0	32.0	1.500	0.000	0.0	0.0
01/14/13	0.0	0.0	32.0	1.500	0.000	0.0	0.0
01/15/13	0.0	0.0	32.0	1.500	0.000	0.0	0.0
01/16/13	0.0	0.0	32.0	1.500	0.000	0.0	0.0
01/17/13	0.0	0.0	32.0	1.500	0.000	0.0	0.0
01/18/13	0.0	0.0	32.0	1.500	0.000	0.0	0.0
01/19/13	0.0	0.0	32.0	1.500	0.000	0.0	0.0
01/21/13	0.0	0.0	32.0	1.500	0.000	0.0	0.0
01/22/13	0.0	0.0	32.0	1.500	0.000	0.0	0.0
01/23/13	0.0	0.0	32.0	1.500	0.000	0.0	0.0
01/24/13	0.0	0.0	32.0	1.500	0.000	0.0	0.0
01/25/13	0.0	0.0	32.0	1.500	0.000	0.0	0.0
01/26/13	0.0	0.0	32.0	1.500	0.000	0.0	0.0
01/27/13	0.0	0.0	32.0	1.500	0.000	0.0	0.0
01/28/13	0.0	0.0	32.0	1.500	0.000	0.0	0.0

3790134

WRA SIRA® TANK REPORT – 03/18/2013

WRA ID : 90637
LOCATION : 00377
TANK ID : 2
PRODUCT : S

PERIOD : 12/29/2012-01/28/2013
SYSTEM CAPACITY : 8000
MDL : 0.010
LEAK RATE : 0.00

EVIDENCE OF POSSIBLE LEAKAGE

Our analysis of your inventory records for this tank shows NO evidence of leakage. We have assumed that stick readings were taken (either manually or by an automatic tank gauge) on all days submitted (including days of no activity). Conclusions presented as to the presence or absence of leakage therefore depend on that assumption.

DATE	SALES	DELIVERIES	STICK READING	INCH1	INCH2	DAILY OVER/SHORT	CUMULATIVE OVER/SHORT
12/29/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
12/30/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
12/31/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
01/01/13	0.0	0.0	35.0	1.875	0.000	0.0	0.0
01/02/13	0.0	0.0	35.0	1.875	0.000	0.0	0.0
01/03/13	0.0	0.0	35.0	1.875	0.000	0.0	0.0
01/04/13	0.0	0.0	35.0	1.875	0.000	0.0	0.0
01/05/13	0.0	0.0	35.0	1.875	0.000	0.0	0.0
01/06/13	0.0	0.0	35.0	1.875	0.000	0.0	0.0
01/07/13	0.0	0.0	35.0	1.875	0.000	0.0	0.0
01/08/13	0.0	0.0	35.0	1.875	0.000	0.0	0.0
01/09/13	0.0	0.0	35.0	1.875	0.000	0.0	0.0
01/10/13	0.0	0.0	35.0	1.875	0.000	0.0	0.0
01/11/13	0.0	0.0	35.0	1.875	0.000	0.0	0.0
01/12/13	0.0	0.0	35.0	1.875	0.000	0.0	0.0
01/13/13	0.0	0.0	35.0	1.875	0.000	0.0	0.0
01/14/13	0.0	0.0	35.0	1.875	0.000	0.0	0.0
01/15/13	0.0	0.0	35.0	1.875	0.000	0.0	0.0
01/16/13	0.0	0.0	35.0	1.875	0.000	0.0	0.0
01/17/13	0.0	0.0	35.0	1.875	0.000	0.0	0.0
01/18/13	0.0	0.0	35.0	1.875	0.000	0.0	0.0
01/19/13	0.0	0.0	35.0	1.875	0.000	0.0	0.0
01/21/13	0.0	0.0	35.0	1.875	0.000	0.0	0.0
01/22/13	0.0	0.0	35.0	1.875	0.000	0.0	0.0
01/23/13	0.0	0.0	35.0	1.875	0.000	0.0	0.0
01/24/13	0.0	0.0	35.0	1.875	0.000	0.0	0.0
01/25/13	0.0	0.0	35.0	1.875	0.000	0.0	0.0
01/26/13	0.0	0.0	35.0	1.875	0.000	0.0	0.0
01/27/13	0.0	0.0	35.0	1.875	0.000	0.0	0.0
01/28/13	0.0	0.0	35.0	1.875	0.000	0.0	0.0

WRA SIRA® TANK REPORT – 03/18/2013

WRA ID : 90637
LOCATION : 00377
TANK ID : 3
PRODUCT : P

PERIOD : 12/29/2012-01/28/2013
SYSTEM CAPACITY : 6000
MDL : 0.010
LEAK RATE : 0.00

EVIDENCE OF POSSIBLE LEAKAGE

Our analysis of your inventory records for this tank shows NO evidence of leakage. We have assumed that stick readings were taken (either manually or by an automatic tank gauge) on all days submitted (including days of no activity). Conclusions presented as to the presence or absence of leakage therefore depend on that assumption.

<u>DATE</u>	<u>SALES</u>	<u>DELIVERIES</u>	<u>STICK READING</u>	<u>INCH1</u>	<u>INCH2</u>	<u>DAILY OVER/SHORT</u>	<u>CUMULATIVE OVER/SHORT</u>
12/29/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
12/30/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
12/31/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
01/01/13	0.0	0.0	49.1	3.000	0.000	0.0	0.0
01/02/13	0.0	0.0	49.1	3.000	0.000	0.0	0.0
01/03/13	0.0	0.0	49.1	3.000	0.000	0.0	0.0
01/04/13	0.0	0.0	49.1	3.000	0.000	0.0	0.0
01/05/13	0.0	0.0	49.1	3.000	0.000	0.0	0.0
01/06/13	0.0	0.0	49.1	3.000	0.000	0.0	0.0
01/07/13	0.0	0.0	49.1	3.000	0.000	0.0	0.0
01/08/13	0.0	0.0	49.1	3.000	0.000	0.0	0.0
01/09/13	0.0	0.0	49.1	3.000	0.000	0.0	0.0
01/10/13	0.0	0.0	49.1	3.000	0.000	0.0	0.0
01/11/13	0.0	0.0	49.1	3.000	0.000	0.0	0.0
01/12/13	0.0	0.0	49.1	3.000	0.000	0.0	0.0
01/13/13	0.0	0.0	49.1	3.000	0.000	0.0	0.0
01/14/13	0.0	0.0	49.1	3.000	0.000	0.0	0.0
01/15/13	0.0	0.0	49.1	3.000	0.000	0.0	0.0
01/16/13	0.0	0.0	49.1	3.000	0.000	0.0	0.0
01/17/13	0.0	0.0	49.1	3.000	0.000	0.0	0.0
01/18/13	0.0	0.0	49.1	3.000	0.000	0.0	0.0
01/19/13	0.0	0.0	49.1	3.000	0.000	0.0	0.0
01/21/13	0.0	0.0	49.1	3.000	0.000	0.0	0.0
01/22/13	0.0	0.0	49.1	3.000	0.000	0.0	0.0
01/23/13	0.0	0.0	49.1	3.000	0.000	0.0	0.0
01/24/13	0.0	0.0	49.1	3.000	0.000	0.0	0.0
01/25/13	0.0	0.0	49.1	3.000	0.000	0.0	0.0
01/26/13	0.0	0.0	49.1	3.000	0.000	0.0	0.0
01/27/13	0.0	0.0	49.1	3.000	0.000	0.0	0.0
01/28/13	0.0	0.0	49.1	3.000	0.000	0.0	0.0

WARREN ROGERS ASSOCIATES, INC.
747 AQUIDNECK AVENUE, MIDDLETOWN, RHODE ISLAND 02842
1-800-WRA-SIRA

MONTHLY STATISTICAL INVENTORY RECONCILIATION (SIR) REPORT

03/18/2013

TANK OWNER	GETTY REALTY CORP.
	125 JERICHO TPKE.
	JERICHO, NY 11753
FACILITY NAME	GETTY REALTY CORP. - 00377 - 00377
TANK LOCATION	40 NORTH MAIN STREET
	NEW CITY, NY 10956

Tank ID- Product	Tank Capacity	Period Covered	Threshold	Minimum Detectable Leak Rate	Measured Leak Rate	System Status Pass, Fail Inconclusive	Monitoring Standards/Cause
	gallons		gph	gph	gph	P,F,I	
1 -R	10000	11/29/2012-12/28/2012	0.005	0.010	0.00	P	NO LOSS-LOW THROUGHPUT OR DORMANT TANK
2 -S	8000	11/29/2012-12/28/2012	0.005	0.010	0.00	P	NO LOSS-LOW THROUGHPUT OR DORMANT TANK
3 -P	6000	11/29/2012-12/28/2012	0.005	0.010	0.00	P	NO LOSS-LOW THROUGHPUT OR DORMANT TANK

Keep this report on file for at least one year.

WRA SIRA® TANK REPORT – 03/18/2013

WRA ID : 90637
LOCATION : 00377
TANK ID : 1
PRODUCT : R

PERIOD : 11/29/2012-12/28/2012
SYSTEM CAPACITY : 10000
MDL : 0.010
LEAK RATE : 0.00

EVIDENCE OF POSSIBLE LEAKAGE

Our analysis of your inventory records for this tank shows NO evidence of leakage. We have assumed that stick readings were taken (either manually or by an automatic tank gauge) on all days submitted (including days of no activity). Conclusions presented as to the presence or absence of leakage therefore depend on that assumption.

<u>DATE</u>	<u>SALES</u>	<u>DELIVERIES</u>	<u>STICK READING</u>	<u>INCH1</u>	<u>INCH2</u>	<u>DAILY OVER/SHORT</u>	<u>CUMULATIVE OVER/SHORT</u>
11/29/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
11/30/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
12/01/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
12/02/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
12/03/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
12/04/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
12/05/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
12/06/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
12/07/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
12/08/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
12/09/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
12/10/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
12/11/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
12/12/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
12/13/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
12/14/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
12/15/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
12/16/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
12/17/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
12/18/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
12/19/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
12/20/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
12/21/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
12/22/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
12/23/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
12/24/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
12/25/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
12/26/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
12/27/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
12/28/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0

WRA SIRA® TANK REPORT – 03/18/2013

WRA ID : 90637
 LOCATION : 00377
 TANK ID : 2
 PRODUCT : S

PERIOD : 11/29/2012-12/28/2012
 SYSTEM CAPACITY : 8000
 MDL : 0.010
 LEAK RATE : 0.00

EVIDENCE OF POSSIBLE LEAKAGE

Our analysis of your inventory records for this tank shows NO evidence of leakage. We have assumed that stick readings were taken (either manually or by an automatic tank gauge) on all days submitted (including days of no activity). Conclusions presented as to the presence or absence of leakage therefore depend on that assumption.

DATE	SALES	DELIVERIES	STICK READING	INCH1	INCH2	DAILY OVER/SHORT	CUMULATIVE OVER/SHORT
11/29/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
11/30/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
12/01/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
12/02/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
12/03/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
12/04/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
12/05/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
12/06/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
12/07/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
12/08/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
12/09/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
12/10/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
12/11/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
12/12/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
12/13/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
12/14/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
12/15/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
12/16/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
12/17/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
12/18/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
12/19/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
12/20/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
12/21/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
12/22/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
12/23/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
12/24/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
12/25/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
12/26/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
12/27/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
12/28/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0

WRA SIRA® TANK REPORT – 03/18/2013

WRA ID : 90637
LOCATION : 00377
TANK ID : 3
PRODUCT : P

PERIOD : 11/29/2012-12/28/2012
SYSTEM CAPACITY : 6000
MDL : 0.010
LEAK RATE : 0.00

EVIDENCE OF POSSIBLE LEAKAGE

Our analysis of your inventory records for this tank shows NO evidence of leakage. We have assumed that stick readings were taken (either manually or by an automatic tank gauge) on all days submitted (including days of no activity). Conclusions presented as to the presence or absence of leakage therefore depend on that assumption.

DATE	SALES	DELIVERIES	STICK READING	INCH1	INCH2	DAILY OVER/SHORT	CUMULATIVE OVER/SHORT
11/29/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
11/30/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
12/01/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
12/02/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
12/03/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
12/04/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
12/05/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
12/06/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
12/07/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
12/08/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
12/09/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
12/10/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
12/11/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
12/12/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
12/13/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
12/14/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
12/15/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
12/16/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
12/17/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
12/18/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
12/19/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
12/20/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
12/21/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
12/22/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
12/23/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
12/24/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
12/25/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
12/26/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
12/27/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
12/28/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0

990124

WARREN ROGERS ASSOCIATES, INC.
747 AQUIDNECK AVENUE, MIDDLETOWN, RHODE ISLAND 02842
1-800-WRA-SIRA

MONTHLY STATISTICAL INVENTORY RECONCILIATION (SIR) REPORT

03/18/2013

TANK OWNER	GETTY REALTY CORP.
	125 JERICHO TPKE.
	JERICHO, NY 11753
FACILITY NAME	GETTY REALTY CORP. - 00377 - 00377
TANK LOCATION	40 NORTH MAIN STREET
	NEW CITY, NY 10956

Tank ID- Product	Tank Capacity	Period Covered	Threshold	Minimum Detectable Leak Rate	Measured Leak Rate	System Status Pass, Fail Inconclusive	Monitoring Standards/Cause
	gallons		gph	gph	gph	P,F,I	
1 -R	10000	10/29/2012-11/28/2012	0.005	0.010	0.00	P	NO LOSS-LOW THROUGHPUT OR DORMANT TANK
2 -S	8000	10/29/2012-11/28/2012	0.005	0.010	0.00	P	NO LOSS-LOW THROUGHPUT OR DORMANT TANK
3 -P	6000	10/29/2012-11/28/2012	0.005	0.010	0.00	P	NO LOSS-LOW THROUGHPUT OR DORMANT TANK

Keep this report on file for at least one year.

WRA SIRA® TANK REPORT – 03/18/2013

WRA ID : 90637
 LOCATION : 00377
 TANK ID : 1
 PRODUCT : R

PERIOD : 10/29/2012-11/28/2012
 SYSTEM CAPACITY : 10000
 MDL : 0.010
 LEAK RATE : 0.00

EVIDENCE OF POSSIBLE LEAKAGE

Our analysis of your inventory records for this tank shows NO evidence of leakage. We have assumed that stick readings were taken (either manually or by an automatic tank gauge) on all days submitted (including days of no activity). Conclusions presented as to the presence or absence of leakage therefore depend on that assumption.

DATE	SALES	DELIVERIES	STICK READING	INCH1	INCH2	DAILY OVER/SHORT	CUMULATIVE OVER/SHORT
10/29/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
10/30/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
10/31/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
11/01/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
11/02/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
11/03/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
11/04/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
11/05/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
11/06/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
11/07/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
11/08/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
11/09/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
11/10/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
11/11/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
11/12/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
11/13/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
11/14/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
11/15/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
11/16/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
11/17/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
11/18/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
11/19/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
11/20/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
11/21/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
11/22/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
11/23/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
11/24/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
11/25/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
11/26/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
11/27/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
11/28/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0

WRA SIRA® TANK REPORT – 03/18/2013

WRA ID : 90637
LOCATION : 00377
TANK ID : 2
PRODUCT : S

PERIOD : 10/29/2012-11/28/2012
SYSTEM CAPACITY : 8000
MDL : 0.010
LEAK RATE : 0.00

EVIDENCE OF POSSIBLE LEAKAGE

Our analysis of your inventory records for this tank shows NO evidence of leakage. We have assumed that stick readings were taken (either manually or by an automatic tank gauge) on all days submitted (including days of no activity). Conclusions presented as to the presence or absence of leakage therefore depend on that assumption.

DATE	SALES	DELIVERIES	STICK READING	INCH1	INCH2	DAILY OVER/SHORT	CUMULATIVE OVER/SHORT
10/29/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
10/30/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
10/31/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
11/01/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
11/02/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
11/03/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
11/04/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
11/05/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
11/06/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
11/07/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
11/08/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
11/09/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
11/10/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
11/11/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
11/12/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
11/13/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
11/14/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
11/15/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
11/16/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
11/17/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
11/18/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
11/19/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
11/20/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
11/21/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
11/22/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
11/23/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
11/24/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
11/25/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
11/26/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
11/27/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
11/28/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0

WRA SIRA® TANK REPORT – 03/18/2013

WRA ID	: 90637	PERIOD	: 10/29/2012-11/28/2012
LOCATION	: 00377	SYSTEM CAPACITY	: 6000
TANK ID	: 3	MDL	: 0.010
PRODUCT	: P	LEAK RATE	: 0.00

EVIDENCE OF POSSIBLE LEAKAGE

Our analysis of your inventory records for this tank shows NO evidence of leakage. We have assumed that stick readings were taken (either manually or by an automatic tank gauge) on all days submitted (including days of no activity). Conclusions presented as to the presence or absence of leakage therefore depend on that assumption.

DATE	SALES	DELIVERIES	STICK READING	INCH1	INCH2	DAILY OVER/SHORT	CUMULATIVE OVER/SHORT
10/29/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
10/30/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
10/31/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
11/01/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
11/02/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
11/03/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
11/04/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
11/05/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
11/06/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
11/07/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
11/08/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
11/09/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
11/10/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
11/11/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
11/12/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
11/13/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
11/14/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
11/15/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
11/16/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
11/17/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
11/18/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
11/19/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
11/20/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
11/21/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
11/22/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
11/23/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
11/24/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
11/25/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
11/26/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
11/27/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
11/28/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0

5 920124

WARREN ROGERS ASSOCIATES, INC.
747 AQUIDNECK AVENUE, MIDDLETOWN, RHODE ISLAND 02842
1-800-WRA-SIRA

MONTHLY STATISTICAL INVENTORY RECONCILIATION (SIR) REPORT

03/18/2013

TANK OWNER	GETTY REALTY CORP.
	125 JERICHO TPKE.
	JERICHO, NY 11753
FACILITY NAME	GETTY REALTY CORP. - 00377 - 00377
TANK LOCATION	40 NORTH MAIN STREET
	NEW CITY, NY 10956

Tank ID- Product	Tank Capacity	Period Covered	Threshold	Minimum Detectable Leak Rate	Measured Leak Rate	System Status Pass, Fail Inconclusive	Monitoring Standards/Cause
	gallons		gph	gph	gph	P,F,I	
1 -R	10000	09/29/2012-10/28/2012	0.005	0.010	0.00	P	NO LOSS-LOW THROUGHPUT OR DORMANT TANK
2 -S	8000	09/29/2012-10/28/2012	0.005	0.010	0.00	P	NO LOSS-LOW THROUGHPUT OR DORMANT TANK
3 -P	6000	09/29/2012-10/28/2012	0.005	0.010	0.00	P	NO LOSS-LOW THROUGHPUT OR DORMANT TANK

Keep this report on file for at least one year.

WRA SIRA® TANK REPORT – 03/18/2013

WRA ID : 90637
LOCATION : 00377
TANK ID : 1
PRODUCT : R

PERIOD : 09/29/2012-10/28/2012
SYSTEM CAPACITY : 10000
MDL : 0.010
LEAK RATE : 0.00

EVIDENCE OF POSSIBLE LEAKAGE

Our analysis of your inventory records for this tank shows NO evidence of leakage. We have assumed that stick readings were taken (either manually or by an automatic tank gauge) on all days submitted (including days of no activity). Conclusions presented as to the presence or absence of leakage therefore depend on that assumption.

<u>DATE</u>	<u>SALES</u>	<u>DELIVERIES</u>	<u>STICK READING</u>	<u>INCH1</u>	<u>INCH2</u>	<u>DAILY OVER/SHORT</u>	<u>CUMULATIVE OVER/SHORT</u>
09/29/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
09/30/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
10/01/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
10/02/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
10/03/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
10/04/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
10/05/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
10/06/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
10/07/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
10/08/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
10/09/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
10/10/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
10/11/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
10/12/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
10/13/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
10/14/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
10/15/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
10/16/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
10/17/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
10/18/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
10/19/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
10/20/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
10/21/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
10/22/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
10/23/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
10/24/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
10/25/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
10/26/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
10/27/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
10/28/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0

WRA SIRA® TANK REPORT – 03/18/2013

WRA ID : 90637
 LOCATION : 00377
 TANK ID : 2
 PRODUCT : S

PERIOD : 09/29/2012-10/28/2012
 SYSTEM CAPACITY : 8000
 MDL : 0.010
 LEAK RATE : 0.00

EVIDENCE OF POSSIBLE LEAKAGE

Our analysis of your inventory records for this tank shows NO evidence of leakage. We have assumed that stick readings were taken (either manually or by an automatic tank gauge) on all days submitted (including days of no activity). Conclusions presented as to the presence or absence of leakage therefore depend on that assumption.

DATE	SALES	DELIVERIES	STICK		INCH2	DAILY	CUMULATIVE
			READING	INCH1		OVER/SHORT	OVER/SHORT
09/29/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
09/30/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
10/01/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
10/02/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
10/03/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
10/04/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
10/05/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
10/06/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
10/07/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
10/08/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
10/09/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
10/10/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
10/11/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
10/12/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
10/13/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
10/14/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
10/15/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
10/16/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
10/17/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
10/18/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
10/19/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
10/20/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
10/21/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
10/22/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
10/23/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
10/24/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
10/25/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
10/26/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
10/27/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
10/28/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0

WRA SIRA® TANK REPORT – 03/18/2013

WRA ID : 90637
LOCATION : 00377
TANK ID : 3
PRODUCT : P

PERIOD : 09/29/2012-10/28/2012
SYSTEM CAPACITY : 6000
MDL : 0.010
LEAK RATE : 0.00

EVIDENCE OF POSSIBLE LEAKAGE

Our analysis of your inventory records for this tank shows NO evidence of leakage. We have assumed that stick readings were taken (either manually or by an automatic tank gauge) on all days submitted (including days of no activity). Conclusions presented as to the presence or absence of leakage therefore depend on that assumption.

<u>DATE</u>	<u>SALES</u>	<u>DELIVERIES</u>	<u>STICK READING</u>	<u>INCH1</u>	<u>INCH2</u>	<u>DAILY OVER/SHORT</u>	<u>CUMULATIVE OVER/SHORT</u>
09/29/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
09/30/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
10/01/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
10/02/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
10/03/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
10/04/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
10/05/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
10/06/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
10/07/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
10/08/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
10/09/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
10/10/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
10/11/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
10/12/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
10/13/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
10/14/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
10/15/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
10/16/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
10/17/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
10/18/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
10/19/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
10/20/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
10/21/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
10/22/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
10/23/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
10/24/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
10/25/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
10/26/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
10/27/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
10/28/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0

2-8801-1

WARREN ROGERS ASSOCIATES, INC.
747 AQUIDNECK AVENUE, MIDDLETOWN, RHODE ISLAND 02842
1-800-WRA-SIRA

MONTHLY STATISTICAL INVENTORY RECONCILIATION (SIR) REPORT

03/18/2013

TANK OWNER	GETTY REALTY CORP.
	125 JERICHO TPKE.
	JERICHO, NY 11753
FACILITY NAME	GETTY REALTY CORP. - 00377 - 00377
TANK LOCATION	40 NORTH MAIN STREET
	NEW CITY, NY 10956

Tank ID- Product	Tank Capacity	Period Covered	Threshold	Minimum Detectable Leak Rate	Measured Leak Rate	System Status Pass, Fail Inconclusive	Monitoring Standards/Cause
	gallons		gph	gph	gph	P,F,I	
1 -R	10000	08/29/2012-09/28/2012	0.005	0.010	0.00	P	NO LOSS-LOW THROUGHPUT OR DORMANT TANK
2 -S	8000	08/29/2012-09/28/2012	0.005	0.010	0.00	P	NO LOSS-LOW THROUGHPUT OR DORMANT TANK
3 -P	6000	08/29/2012-09/28/2012	0.005	0.010	0.00	P	NO LOSS-LOW THROUGHPUT OR DORMANT TANK

Keep this report on file for at least one year.

WRA SIRA® TANK REPORT – 03/18/2013

WRA ID : 90637
 LOCATION : 00377
 TANK ID : 1
 PRODUCT : R

PERIOD : 08/29/2012-09/28/2012
 SYSTEM CAPACITY : 10000
 MDL : 0.010
 LEAK RATE : 0.00

EVIDENCE OF POSSIBLE LEAKAGE

Our analysis of your inventory records for this tank shows NO evidence of leakage. We have assumed that stick readings were taken (either manually or by an automatic tank gauge) on all days submitted (including days of no activity). Conclusions presented as to the presence or absence of leakage therefore depend on that assumption.

DATE	SALES	DELIVERIES	STICK READING	INCH1	INCH2	DAILY OVER/SHORT	CUMULATIVE OVER/SHORT
08/29/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
08/30/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
08/31/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
09/01/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
09/02/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
09/03/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
09/04/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
09/05/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
09/06/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
09/07/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
09/08/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
09/09/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
09/10/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
09/11/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
09/12/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
09/13/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
09/14/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
09/15/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
09/16/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
09/17/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
09/18/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
09/19/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
09/20/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
09/21/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
09/22/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
09/23/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
09/24/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
09/25/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
09/26/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
09/27/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
09/28/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0

5 790125

WRA SIRA® TANK REPORT – 03/18/2013

WRA ID : 90637
LOCATION : 00377
TANK ID : 2
PRODUCT : S

PERIOD : 08/29/2012-09/28/2012
SYSTEM CAPACITY : 8000
MDL : 0.010
LEAK RATE : 0.00

EVIDENCE OF POSSIBLE LEAKAGE

Our analysis of your inventory records for this tank shows NO evidence of leakage. We have assumed that stick readings were taken (either manually or by an automatic tank gauge) on all days submitted (including days of no activity). Conclusions presented as to the presence or absence of leakage therefore depend on that assumption.

DATE	SALES	DELIVERIES	STICK READING	INCH1	INCH2	DAILY OVER/SHORT	CUMULATIVE OVER/SHORT
08/29/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
08/30/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
08/31/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
09/01/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
09/02/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
09/03/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
09/04/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
09/05/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
09/06/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
09/07/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
09/08/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
09/09/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
09/10/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
09/11/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
09/12/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
09/13/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
09/14/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
09/15/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
09/16/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
09/17/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
09/18/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
09/19/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
09/20/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
09/21/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
09/22/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
09/23/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
09/24/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
09/25/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
09/26/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
09/27/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
09/28/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0

WRA SIRA® TANK REPORT – 03/18/2013

WRA ID	: 90637	PERIOD	: 08/29/2012-09/28/2012
LOCATION	: 00377	SYSTEM CAPACITY	: 6000
TANK ID	: 3	MDL	: 0.010
PRODUCT	: P	LEAK RATE	: 0.00

EVIDENCE OF POSSIBLE LEAKAGE

Our analysis of your inventory records for this tank shows NO evidence of leakage. We have assumed that stick readings were taken (either manually or by an automatic tank gauge) on all days submitted (including days of no activity). Conclusions presented as to the presence or absence of leakage therefore depend on that assumption.

DATE	SALES	DELIVERIES	STICK READING	INCH1	INCH2	DAILY OVER/SHORT	CUMULATIVE OVER/SHORT
08/29/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
08/30/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
08/31/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
09/01/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
09/02/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
09/03/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
09/04/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
09/05/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
09/06/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
09/07/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
09/08/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
09/09/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
09/10/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
09/11/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
09/12/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
09/13/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
09/14/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
09/15/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
09/16/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
09/17/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
09/18/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
09/19/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
09/20/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
09/21/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
09/22/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
09/23/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
09/24/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
09/25/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
09/26/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
09/27/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
09/28/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0

WARREN ROGERS ASSOCIATES, INC.
747 AQUIDNECK AVENUE, MIDDLETOWN, RHODE ISLAND 02842
1-800-WRA-SIRA

MONTHLY STATISTICAL INVENTORY RECONCILIATION (SIR) REPORT

03/18/2013

TANK OWNER	GETTY REALTY CORP.
	125 JERICHO TPKE.
	JERICHO, NY 11753
FACILITY NAME	GETTY REALTY CORP. - 00377 - 00377
TANK LOCATION	40 NORTH MAIN STREET
	NEW CITY, NY 10956

Tank ID- Product	Tank Capacity	Period Covered	Threshold	Minimum Detectable Leak Rate	Measured Leak Rate	System Status Pass, Fail Inconclusive	Monitoring Standards/Cause
	gallons		gph	gph	gph	P,F,I	
1 -R	10000	07/29/2012-08/28/2012	0.005	0.010	0.00	P	NO LOSS-LOW THROUGHPUT OR DORMANT TANK
2 -S	8000	07/29/2012-08/28/2012	0.005	0.010	0.00	P	NO LOSS-LOW THROUGHPUT OR DORMANT TANK
3 -P	6000	07/29/2012-08/28/2012	0.005	0.010	0.00	P	NO LOSS-LOW THROUGHPUT OR DORMANT TANK

Keep this report on file for at least one year.

WRA SIRA® TANK REPORT – 03/18/2013

WRA ID : 90637
 LOCATION : 00377
 TANK ID : 1
 PRODUCT : R

PERIOD : 07/29/2012-08/28/2012
 SYSTEM CAPACITY : 10000
 MDL : 0.010
 LEAK RATE : 0.00

EVIDENCE OF POSSIBLE LEAKAGE

Our analysis of your inventory records for this tank shows NO evidence of leakage. We have assumed that stick readings were taken (either manually or by an automatic tank gauge) on all days submitted (including days of no activity). Conclusions presented as to the presence or absence of leakage therefore depend on that assumption.

DATE	SALES	DELIVERIES	STICK READING	INCH1	INCH2	DAILY OVER/SHORT	CUMULATIVE OVER/SHORT
07/29/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
07/30/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
07/31/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
08/01/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
08/02/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
08/03/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
08/04/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
08/05/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
08/06/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
08/07/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
08/08/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
08/09/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
08/10/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
08/11/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
08/12/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
08/13/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
08/14/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
08/15/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
08/16/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
08/17/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
08/18/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
08/19/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
08/20/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
08/21/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
08/22/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
08/23/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
08/24/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
08/25/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
08/26/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
08/27/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
08/28/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0

WRA SIRA® TANK REPORT – 03/18/2013

WRA ID : 90637
 LOCATION : 00377
 TANK ID : 2
 PRODUCT : S

PERIOD : 07/29/2012-08/28/2012
 SYSTEM CAPACITY : 8000
 MDL : 0.010
 LEAK RATE : 0.00

EVIDENCE OF POSSIBLE LEAKAGE

Our analysis of your inventory records for this tank shows NO evidence of leakage. We have assumed that stick readings were taken (either manually or by an automatic tank gauge) on all days submitted (including days of no activity). Conclusions presented as to the presence or absence of leakage therefore depend on that assumption.

DATE	SALES	DELIVERIES	STICK READING	INCH1	INCH2	DAILY OVER/SHORT	CUMULATIVE OVER/SHORT
07/29/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
07/30/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
07/31/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
08/01/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
08/02/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
08/03/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
08/04/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
08/05/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
08/06/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
08/07/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
08/08/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
08/09/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
08/10/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
08/11/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
08/12/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
08/13/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
08/14/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
08/15/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
08/16/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
08/17/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
08/18/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
08/19/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
08/20/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
08/21/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
08/22/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
08/23/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
08/24/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
08/25/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
08/26/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
08/27/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
08/28/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0

WRA SIRA® TANK REPORT – 03/18/2013

WRA ID : 90637
LOCATION : 00377
TANK ID : 3
PRODUCT : P

PERIOD : 07/29/2012-08/28/2012
SYSTEM CAPACITY : 6000
MDL : 0.010
LEAK RATE : 0.00

EVIDENCE OF POSSIBLE LEAKAGE

Our analysis of your inventory records for this tank shows NO evidence of leakage. We have assumed that stick readings were taken (either manually or by an automatic tank gauge) on all days submitted (including days of no activity). Conclusions presented as to the presence or absence of leakage therefore depend on that assumption.

DATE	SALES	DELIVERIES	STICK READING	INCH1	INCH2	DAILY OVER/SHORT	CUMULATIVE OVER/SHORT
07/29/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
07/30/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
07/31/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
08/01/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
08/02/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
08/03/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
08/04/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
08/05/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
08/06/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
08/07/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
08/08/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
08/09/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
08/10/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
08/11/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
08/12/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
08/13/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
08/14/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
08/15/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
08/16/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
08/17/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
08/18/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
08/19/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
08/20/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
08/21/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
08/22/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
08/23/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
08/24/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
08/25/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
08/26/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
08/27/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
08/28/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0

2-1190178

WARREN ROGERS ASSOCIATES, INC.
747 AQUIDNECK AVENUE, MIDDLETOWN, RHODE ISLAND 02842
1-800-WRA-SIRA

MONTHLY STATISTICAL INVENTORY RECONCILIATION (SIR) REPORT

03/18/2013

TANK OWNER	GETTY REALTY CORP.
	125 JERICHO TPKE.
	JERICHO, NY 11753
FACILITY NAME	GETTY REALTY CORP. - 00377 - 00377
TANK LOCATION	40 NORTH MAIN STREET
	NEW CITY, NY 10956

Tank ID- Product	Tank Capacity	Period Covered	Threshold	Minimum Detectable Leak Rate	Measured Leak Rate	System Status Pass, Fail Inconclusive	Monitoring Standards/Cause
	gallons		gph	gph	gph	P,F,I	
1 -R	10000	06/29/2012-07/28/2012	0.005	0.010	0.00	P	NO LOSS-LOW THROUGHPUT OR DORMANT TANK
2 -S	8000	06/29/2012-07/28/2012	0.005	0.010	0.00	P	NO LOSS-LOW THROUGHPUT OR DORMANT TANK
3 -P	6000	06/29/2012-07/28/2012	0.005	0.010	0.00	P	NO LOSS-LOW THROUGHPUT OR DORMANT TANK

Keep this report on file for at least one year.

WRA SIRA® TANK REPORT – 03/18/2013

WRA ID : 90637
LOCATION : 00377
TANK ID : 1
PRODUCT : R

PERIOD : 06/29/2012-07/28/2012
SYSTEM CAPACITY : 10000
MDL : 0.010
LEAK RATE : 0.00

EVIDENCE OF POSSIBLE LEAKAGE

Our analysis of your inventory records for this tank shows NO evidence of leakage. We have assumed that stick readings were taken (either manually or by an automatic tank gauge) on all days submitted (including days of no activity). Conclusions presented as to the presence or absence of leakage therefore depend on that assumption.

<u>DATE</u>	<u>SALES</u>	<u>DELIVERIES</u>	<u>STICK READING</u>	<u>INCH1</u>	<u>INCH2</u>	<u>DAILY OVER/SHORT</u>	<u>CUMULATIVE OVER/SHORT</u>
06/29/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
06/30/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
07/01/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
07/02/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
07/03/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
07/04/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
07/05/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
07/06/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
07/07/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
07/08/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
07/09/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
07/10/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
07/11/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
07/12/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
07/13/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
07/14/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
07/15/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
07/16/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
07/17/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
07/18/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
07/19/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
07/20/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
07/21/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
07/22/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
07/23/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
07/24/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
07/25/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
07/26/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
07/27/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
07/28/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0

WRA SIRA® TANK REPORT – 03/18/2013

WRA ID : 90637
 LOCATION : 00377
 TANK ID : 2
 PRODUCT : S

PERIOD : 06/29/2012-07/28/2012
 SYSTEM CAPACITY : 8000
 MDL : 0.010
 LEAK RATE : 0.00

EVIDENCE OF POSSIBLE LEAKAGE

Our analysis of your inventory records for this tank shows NO evidence of leakage. We have assumed that stick readings were taken (either manually or by an automatic tank gauge) on all days submitted (including days of no activity). Conclusions presented as to the presence or absence of leakage therefore depend on that assumption.

DATE	SALES	DELIVERIES	STICK READING	INCH1	INCH2	DAILY OVER/SHORT	CUMULATIVE OVER/SHORT
06/29/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
06/30/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
07/01/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
07/02/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
07/03/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
07/04/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
07/05/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
07/06/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
07/07/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
07/08/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
07/09/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
07/10/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
07/11/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
07/12/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
07/13/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
07/14/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
07/15/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
07/16/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
07/17/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
07/18/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
07/19/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
07/20/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
07/21/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
07/22/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
07/23/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
07/24/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
07/25/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
07/26/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
07/27/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
07/28/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0

WRA SIRA® TANK REPORT – 03/18/2013

WRA ID : 90637
LOCATION : 00377
TANK ID : 3
PRODUCT : P

PERIOD : 06/29/2012-07/28/2012
SYSTEM CAPACITY : 6000
MDL : 0.010
LEAK RATE : 0.00

EVIDENCE OF POSSIBLE LEAKAGE

Our analysis of your inventory records for this tank shows NO evidence of leakage. We have assumed that stick readings were taken (either manually or by an automatic tank gauge) on all days submitted (including days of no activity). Conclusions presented as to the presence or absence of leakage therefore depend on that assumption.

DATE	SALES	DELIVERIES	STICK READING	INCH1	INCH2	DAILY OVER/SHORT	CUMULATIVE OVER/SHORT
06/29/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
06/30/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
07/01/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
07/02/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
07/03/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
07/04/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
07/05/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
07/06/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
07/07/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
07/08/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
07/09/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
07/10/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
07/11/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
07/12/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
07/13/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
07/14/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
07/15/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
07/16/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
07/17/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
07/18/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
07/19/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
07/20/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
07/21/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
07/22/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
07/23/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
07/24/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
07/25/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
07/26/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
07/27/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
07/28/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0

3-18-13

WARREN ROGERS ASSOCIATES, INC.
747 AQUIDNECK AVENUE, MIDDLETOWN, RHODE ISLAND 02842
1-800-WRA-SIRA

MONTHLY STATISTICAL INVENTORY RECONCILIATION (SIR) REPORT

03/18/2013

TANK OWNER	GETTY REALTY CORP.
	125 JERICHO TPKE.
	JERICHO, NY 11753
FACILITY NAME	GETTY REALTY CORP. - 00377 - 00377
TANK LOCATION	40 NORTH MAIN STREET
	NEW CITY, NY 10956

Tank ID- Product	Tank Capacity	Period Covered	Threshold	Minimum Detectable Leak Rate	Measured Leak Rate	System Status Pass, Fail Inconclusive	Monitoring Standards/Cause
	gallons		gph	gph	gph	P,F,I	
1 -R	10000	05/29/2012-06/28/2012	0.005	0.010	0.00	P	NO LOSS-LOW THROUGHPUT OR DORMANT TANK
2 -S	8000	05/29/2012-06/28/2012	0.005	0.010	0.00	P	NO LOSS-LOW THROUGHPUT OR DORMANT TANK
3 -P	6000	05/29/2012-06/28/2012	0.005	0.010	0.00	P	NO LOSS-LOW THROUGHPUT OR DORMANT TANK

Keep this report on file for at least one year.

WRA SIRA® TANK REPORT – 03/18/2013

WRA ID : 90637
LOCATION : 00377
TANK ID : 1
PRODUCT : R

PERIOD : 05/29/2012-06/28/2012
SYSTEM CAPACITY : 10000
MDL : 0.010
LEAK RATE : 0.00

EVIDENCE OF POSSIBLE LEAKAGE

Our analysis of your inventory records for this tank shows NO evidence of leakage. We have assumed that stick readings were taken (either manually or by an automatic tank gauge) on all days submitted (including days of no activity). Conclusions presented as to the presence or absence of leakage therefore depend on that assumption.

<u>DATE</u>	<u>SALES</u>	<u>DELIVERIES</u>	<u>STICK READING</u>	<u>INCH1</u>	<u>INCH2</u>	<u>DAILY OVER/SHORT</u>	<u>CUMULATIVE OVER/SHORT</u>
05/29/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
05/30/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
05/31/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
06/01/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
06/02/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
06/03/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
06/04/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
06/05/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
06/06/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
06/07/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
06/08/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
06/09/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
06/10/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
06/11/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
06/12/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
06/13/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
06/14/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
06/15/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
06/16/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
06/17/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
06/18/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
06/19/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
06/20/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
06/21/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
06/22/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
06/23/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
06/24/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
06/25/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
06/26/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
06/27/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
06/28/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0

WRA SIRA® TANK REPORT – 03/18/2013

WRA ID : 90637
LOCATION : 00377
TANK ID : 2
PRODUCT : S

PERIOD : 05/29/2012-06/28/2012
SYSTEM CAPACITY : 8000
MDL : 0.010
LEAK RATE : 0.00

EVIDENCE OF POSSIBLE LEAKAGE

Our analysis of your inventory records for this tank shows NO evidence of leakage. We have assumed that stick readings were taken (either manually or by an automatic tank gauge) on all days submitted (including days of no activity). Conclusions presented as to the presence or absence of leakage therefore depend on that assumption.

DATE	SALES	DELIVERIES	STICK READING	INCH1	INCH2	DAILY OVER/SHORT	CUMULATIVE OVER/SHORT
05/29/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
05/30/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
05/31/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
06/01/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
06/02/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
06/03/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
06/04/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
06/05/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
06/06/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
06/07/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
06/08/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
06/09/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
06/10/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
06/11/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
06/12/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
06/13/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
06/14/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
06/15/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
06/16/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
06/17/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
06/18/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
06/19/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
06/20/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
06/21/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
06/22/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
06/23/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
06/24/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
06/25/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
06/26/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
06/27/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
06/28/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0

WRA SIRA® TANK REPORT – 03/18/2013

WRA ID	: 90637	PERIOD	: 05/29/2012-06/28/2012
LOCATION	: 00377	SYSTEM CAPACITY	: 6000
TANK ID	: 3	MDL	: 0.010
PRODUCT	: P	LEAK RATE	: 0.00

EVIDENCE OF POSSIBLE LEAKAGE

Our analysis of your inventory records for this tank shows NO evidence of leakage. We have assumed that stick readings were taken (either manually or by an automatic tank gauge) on all days submitted (including days of no activity). Conclusions presented as to the presence or absence of leakage therefore depend on that assumption.

DATE	SALES	DELIVERIES	STICK READING	INCH1	INCH2	DAILY OVER/SHORT	CUMULATIVE OVER/SHORT
05/29/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
05/30/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
05/31/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
06/01/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
06/02/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
06/03/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
06/04/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
06/05/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
06/06/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
06/07/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
06/08/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
06/09/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
06/10/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
06/11/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
06/12/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
06/13/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
06/14/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
06/15/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
06/16/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
06/17/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
06/18/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
06/19/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
06/20/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
06/21/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
06/22/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
06/23/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
06/24/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
06/25/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
06/26/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
06/27/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
06/28/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0

WARREN ROGERS ASSOCIATES, INC.
747 AQUIDNECK AVENUE, MIDDLETOWN, RHODE ISLAND 02842
1-800-WRA-SIRA

MONTHLY STATISTICAL INVENTORY RECONCILIATION (SIR) REPORT

03/18/2013

TANK OWNER	GETTY REALTY CORP.
	125 JERICHO TPKE.
	JERICHO, NY 11753
FACILITY NAME	GETTY REALTY CORP. - 00377 - 00377
TANK LOCATION	40 NORTH MAIN STREET
	NEW CITY, NY 10956

Tank ID- Product	Tank Capacity	Period Covered	Threshold	Minimum Detectable Leak Rate	Measured Leak Rate	System Status Pass, Fail Inconclusive	Monitoring Standards/Cause
	gallons		gph	gph	gph	P,F,I	
1 -R	10000	04/29/2012-05/28/2012	0.005	0.010	0.00	P	NO LOSS-LOW THROUGHPUT OR DORMANT TANK
2 -S	8000	04/29/2012-05/28/2012	0.005	0.010	0.00	P	NO LOSS-LOW THROUGHPUT OR DORMANT TANK
3 -P	6000	04/29/2012-05/28/2012	0.005	0.010	0.00	P	NO LOSS-LOW THROUGHPUT OR DORMANT TANK

Keep this report on file for at least one year.

WRA SIRA® TANK REPORT – 03/18/2013

WRA ID : 90637
LOCATION : 00377
TANK ID : 1
PRODUCT : R

PERIOD : 04/29/2012-05/28/2012
SYSTEM CAPACITY : 10000
MDL : 0.010
LEAK RATE : 0.00

EVIDENCE OF POSSIBLE LEAKAGE

Our analysis of your inventory records for this tank shows NO evidence of leakage. We have assumed that stick readings were taken (either manually or by an automatic tank gauge) on all days submitted (including days of no activity). Conclusions presented as to the presence or absence of leakage therefore depend on that assumption.

DATE	SALES	DELIVERIES	STICK READING	INCH1	INCH2	DAILY OVER/SHORT	CUMULATIVE OVER/SHORT
04/29/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
04/30/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
05/01/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
05/02/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
05/03/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
05/04/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
05/05/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
05/06/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
05/07/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
05/08/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
05/09/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
05/10/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
05/11/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
05/12/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
05/13/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
05/14/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
05/15/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
05/16/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
05/17/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
05/18/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
05/19/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
05/20/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
05/21/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
05/22/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
05/23/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
05/24/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
05/25/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
05/26/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
05/27/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
05/28/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0

WRA SIRA® TANK REPORT – 03/18/2013

WRA ID : 90637
 LOCATION : 00377
 TANK ID : 2
 PRODUCT : S

PERIOD : 04/29/2012-05/28/2012
 SYSTEM CAPACITY : 8000
 MDL : 0.010
 LEAK RATE : 0.00

EVIDENCE OF POSSIBLE LEAKAGE

Our analysis of your inventory records for this tank shows NO evidence of leakage. We have assumed that stick readings were taken (either manually or by an automatic tank gauge) on all days submitted (including days of no activity). Conclusions presented as to the presence or absence of leakage therefore depend on that assumption.

DATE	SALES	DELIVERIES	STICK		INCH2	DAILY	CUMULATIVE
			READING	INCH1		OVER/SHORT	OVER/SHORT
04/29/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
04/30/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
05/01/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
05/02/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
05/03/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
05/04/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
05/05/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
05/06/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
05/07/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
05/08/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
05/09/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
05/10/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
05/11/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
05/12/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
05/13/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
05/14/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
05/15/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
05/16/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
05/17/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
05/18/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
05/19/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
05/20/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
05/21/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
05/22/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
05/23/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
05/24/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
05/25/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
05/26/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
05/27/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
05/28/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0

WRA SIRA® TANK REPORT – 03/18/2013

WRA ID : 90637
LOCATION : 00377
TANK ID : 3
PRODUCT : P

PERIOD : 04/29/2012-05/28/2012
SYSTEM CAPACITY : 6000
MDL : 0.010
LEAK RATE : 0.00

EVIDENCE OF POSSIBLE LEAKAGE

Our analysis of your inventory records for this tank shows NO evidence of leakage. We have assumed that stick readings were taken (either manually or by an automatic tank gauge) on all days submitted (including days of no activity). Conclusions presented as to the presence or absence of leakage therefore depend on that assumption.

DATE	SALES	DELIVERIES	STICK READING	INCH1	INCH2	DAILY OVER/SHORT	CUMULATIVE OVER/SHORT
04/29/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
04/30/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
05/01/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
05/02/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
05/03/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
05/04/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
05/05/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
05/06/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
05/07/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
05/08/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
05/09/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
05/10/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
05/11/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
05/12/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
05/13/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
05/14/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
05/15/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
05/16/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
05/17/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
05/18/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
05/19/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
05/20/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
05/21/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
05/22/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
05/23/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
05/24/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
05/25/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
05/26/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
05/27/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
05/28/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0

500000

WARREN ROGERS ASSOCIATES, INC.
747 AQUIDNECK AVENUE, MIDDLETOWN, RHODE ISLAND 02842
1-800-WRA-SIRA

MONTHLY STATISTICAL INVENTORY RECONCILIATION (SIR) REPORT

05/02/2012

TANK OWNER	GETTY PETROLEUM MARKETING INC.
	1500 HEMPSTEAD TURNPIKE
	EAST MEADOW, NY 11554
FACILITY NAME	GETTY PETROLEUM CORP - 00377 - 00377
TANK LOCATION	40 NORTH MAIN STREET
	NEW CITY, NY 10956

Tank ID- Product	Tank Capacity	Period Covered	Threshold	Minimum Detectable Leak Rate	Measured Leak Rate	System Status Pass, Fail Inconclusive	Monitoring Standards/Cause
	gallons		gph	gph	gph	P,F,I	
1 -R	10000	03/29/2012-04/28/2012	0.005	0.010	0.00	P	INACTIVE OR DORMANT TANK
2 -S	8000	03/29/2012-04/28/2012	0.005	0.010	0.00	P	INACTIVE OR DORMANT TANK
3 -P	6000	03/29/2012-04/28/2012	0.005	0.010	0.00	P	INACTIVE OR DORMANT TANK

Keep this report on file for at least one year.

WRA SIRA® TANK REPORT – 05/02/2012

WRA ID : 90107
LOCATION : 00377
TANK ID : 1
PRODUCT : R

PERIOD : 03/29/2012-04/28/2012
SYSTEM CAPACITY : 10000
MDL : 0.010
LEAK RATE : 0.00

EVIDENCE OF POSSIBLE LEAKAGE

Our analysis of your inventory records for this tank shows NO evidence of leakage. We have assumed that stick readings were taken (either manually or by an automatic tank gauge) on all days submitted (including days of no activity). Conclusions presented as to the presence or absence of leakage therefore depend on that assumption.

DATE	SALES	DELIVERIES	STICK READING	INCH1	INCH2	DAILY OVER/SHORT	CUMULATIVE OVER/SHORT
03/29/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
03/30/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
03/31/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
04/01/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
04/02/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
04/03/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
04/04/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
04/05/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
04/06/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
04/07/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
04/08/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
04/09/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
04/10/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
04/11/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
04/12/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
04/13/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
04/14/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
04/15/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
04/16/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
04/17/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
04/18/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
04/19/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
04/20/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
04/21/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
04/22/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
04/23/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0

31990151

WRA SIRA® TANK REPORT – 05/02/2012

WRA ID : 90107
LOCATION : 00377
TANK ID : 2
PRODUCT : S

PERIOD : 03/29/2012-04/28/2012
SYSTEM CAPACITY : 8000
MDL : 0.010
LEAK RATE : 0.00

EVIDENCE OF POSSIBLE LEAKAGE

Our analysis of your inventory records for this tank shows NO evidence of leakage. We have assumed that stick readings were taken (either manually or by an automatic tank gauge) on all days submitted (including days of no activity). Conclusions presented as to the presence or absence of leakage therefore depend on that assumption.

DATE	SALES	DELIVERIES	STICK READING	INCH1	INCH2	DAILY OVER/SHORT	CUMULATIVE OVER/SHORT
03/29/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
03/30/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
03/31/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
04/01/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
04/02/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
04/03/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
04/04/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
04/05/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
04/06/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
04/07/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
04/08/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
04/09/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
04/10/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
04/11/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
04/12/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
04/13/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
04/14/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
04/15/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
04/16/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
04/17/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
04/18/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
04/19/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
04/20/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
04/21/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
04/22/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
04/23/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0

WRA SIRA® TANK REPORT – 05/02/2012

WRA ID : 90107
LOCATION : 00377
TANK ID : 3
PRODUCT : P

PERIOD : 03/29/2012-04/28/2012
SYSTEM CAPACITY : 6000
MDL : 0.010
LEAK RATE : 0.00

EVIDENCE OF POSSIBLE LEAKAGE

Our analysis of your inventory records for this tank shows NO evidence of leakage. We have assumed that stick readings were taken (either manually or by an automatic tank gauge) on all days submitted (including days of no activity). Conclusions presented as to the presence or absence of leakage therefore depend on that assumption.

<u>DATE</u>	<u>SALES</u>	<u>DELIVERIES</u>	<u>STICK READING</u>	<u>INCH1</u>	<u>INCH2</u>	<u>DAILY OVER/SHORT</u>	<u>CUMULATIVE OVER/SHORT</u>
03/29/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
03/30/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
03/31/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
04/01/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
04/02/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
04/03/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
04/04/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
04/05/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
04/06/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
04/07/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
04/08/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
04/09/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
04/10/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
04/11/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
04/12/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
04/13/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
04/14/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
04/15/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
04/16/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
04/17/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
04/18/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
04/19/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
04/20/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
04/21/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
04/22/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
04/23/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0

WARREN ROGERS ASSOCIATES, INC.
747 AQUIDNECK AVENUE, MIDDLETOWN, RHODE ISLAND 02842
1-800-WRA-SIRA

MONTHLY STATISTICAL INVENTORY RECONCILIATION (SIR) REPORT

04/04/2012

TANK OWNER	GETTY PETROLEUM MARKETING INC.
	1500 HEMPSTEAD TURNPIKE
	EAST MEADOW, NY 11554
FACILITY NAME	GETTY PETROLEUM CORP - 00377 - 00377
TANK LOCATION	40 NORTH MAIN STREET
	NEW CITY, NY 10956

Tank ID- Product	Tank Capacity	Period Covered	Threshold	Minimum Detectable Leak Rate	Measured Leak Rate	System Status Pass, Fail Inconclusive	Monitoring Standards/Cause
	gallons		gph	gph	gph	P,F,I	
1 -R	10000	02/29/2012-03/28/2012	0.005	0.010	0.00	P	INACTIVE OR DORMANT TANK
2 -S	8000	02/29/2012-03/28/2012	0.005	0.010	0.00	P	INACTIVE OR DORMANT TANK
3 -P	6000	02/29/2012-03/28/2012	0.005	0.010	0.00	P	INACTIVE OR DORMANT TANK

Keep this report on file for at least one year.

WRA SIRA® TANK REPORT – 04/04/2012

WRA ID : 90107
LOCATION : 00377
TANK ID : 1
PRODUCT : R

PERIOD : 02/29/2012-03/28/2012
SYSTEM CAPACITY : 10000
MDL : 0.010
LEAK RATE : 0.00

EVIDENCE OF POSSIBLE LEAKAGE

Our analysis of your inventory records for this tank shows NO evidence of leakage. We have assumed that stick readings were taken (either manually or by an automatic tank gauge) on all days submitted (including days of no activity). Conclusions presented as to the presence or absence of leakage therefore depend on that assumption.

DATE	SALES	DELIVERIES	STICK READING	INCH1	INCH2	DAILY OVER/SHORT	CUMULATIVE OVER/SHORT
02/29/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
03/01/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
03/02/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
03/03/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
03/04/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
03/05/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
03/06/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
03/07/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
03/08/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
03/09/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
03/10/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
03/11/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
03/12/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
03/13/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
03/14/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
03/15/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
03/16/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
03/17/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
03/18/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
03/19/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
03/20/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
03/21/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
03/22/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
03/23/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
03/24/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
03/25/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
03/26/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
03/27/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0
03/28/12	0.0	0.0	32.0	1.500	0.000	0.0	0.0

WRA SIRA® TANK REPORT – 04/04/2012

WRA ID : 90107
 LOCATION : 00377
 TANK ID : 2
 PRODUCT : S

PERIOD : 02/29/2012-03/28/2012
 SYSTEM CAPACITY : 8000
 MDL : 0.010
 LEAK RATE : 0.00

EVIDENCE OF POSSIBLE LEAKAGE

Our analysis of your inventory records for this tank shows NO evidence of leakage. We have assumed that stick readings were taken (either manually or by an automatic tank gauge) on all days submitted (including days of no activity). Conclusions presented as to the presence or absence of leakage therefore depend on that assumption.

DATE	SALES	DELIVERIES	STICK READING	INCH1	INCH2	DAILY OVER/SHORT	CUMULATIVE OVER/SHORT
02/29/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
03/01/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
03/02/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
03/03/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
03/04/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
03/05/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
03/06/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
03/07/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
03/08/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
03/09/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
03/10/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
03/11/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
03/12/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
03/13/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
03/14/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
03/15/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
03/16/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
03/17/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
03/18/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
03/19/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
03/20/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
03/21/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
03/22/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
03/23/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
03/24/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
03/25/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
03/26/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
03/27/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0
03/28/12	0.0	0.0	35.0	1.875	0.000	0.0	0.0

WRA SIRA® TANK REPORT – 04/04/2012

WRA ID : 90107
LOCATION : 00377
TANK ID : 3
PRODUCT : P

PERIOD : 02/29/2012-03/28/2012
SYSTEM CAPACITY : 6000
MDL : 0.010
LEAK RATE : 0.00

EVIDENCE OF POSSIBLE LEAKAGE

Our analysis of your inventory records for this tank shows NO evidence of leakage. We have assumed that stick readings were taken (either manually or by an automatic tank gauge) on all days submitted (including days of no activity). Conclusions presented as to the presence or absence of leakage therefore depend on that assumption.

DATE	SALES	DELIVERIES	STICK READING	INCH1	INCH2	DAILY OVER/SHORT	CUMULATIVE OVER/SHORT
02/29/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
03/01/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
03/02/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
03/03/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
03/04/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
03/05/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
03/06/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
03/07/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
03/08/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
03/09/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
03/10/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
03/11/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
03/12/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
03/13/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
03/14/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
03/15/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
03/16/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
03/17/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
03/18/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
03/19/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
03/20/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
03/21/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
03/22/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
03/23/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
03/24/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
03/25/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
03/26/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
03/27/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0
03/28/12	0.0	0.0	49.1	3.000	0.000	0.0	0.0

381



382



3-990136



383



384


385



386



3-990136



387



388

389




390

8-990136



391



392

393

3-990186

